

CLASSIFICATION OF FUNCTIONAL RESISTANCE FIRES-CR-019-17-AUPE

Power and communication cables of Technokabel S.A. at cable supporting system BAKS

This is an electronic version of a classification report which was made as a copy of classification report officially issued in a paper form. The electronic version of a classification report shall be used only for informative purpose. Any information listed in this classification report is the property of the sponsor and shall not be used or published without written permission. Contents of this file may only be modified by the editor i.e. FIRES, s.r.o., Batizovce. Sponsor is allowed to publish this classification report in parts only with written permission of the editor.



CLASSIFICATION OF FUNCTIONAL RESISTANCE IN FIRE IN ACCORDANCE WITH DIN 4102-12: 1998-11 with direct field of application

FIRES-CR-019-17-AUPE

Name of the product: Power and communication cables of Technokabel S.A. at cable supporting system BAKS

Sponsor: Technokabel S.A.
Nasielska 55
04 – 343 Warszawa
Poland

Prepared by: FIRES, s.r.o.
Notified Body No. 1396
Osloboditeľov 282
059 35 Batizovce
Slovak Republic

Task No.: PR-17-0003

Date of issue: 16. 02. 2017

Reports: 5

Copy No.: 3

Distribution list:

Copy No. 1 FIRES, s. r. o., Osloboditeľov 282, 059 35 Batizovce, Slovak Republic
(electronic version)

Copy No. 2 Technokabel S.A., Nasielska 55, 04 – 343 Warszawa, Poland
(electronic version)

Copy No. 3 BAKS Kazimierz Sielski, ul. Jagodne 5, 05-480 Karczew, Poland
(electronic version)

Copy No. 4 Technokabel S.A., Nasielska 55, 04 – 343 Warszawa, Poland

Copy No. 5 BAKS Kazimierz Sielski, ul. Jagodne 5, 05-480 Karczew, Poland

This classification report may only be used or reproduced in its entirety.

This report includes accreditation mark SNAS with additional mark ILAC-MRA. SNAS is signatory of ILAC-MRA, Mutual recognition agreement (of accreditation), which is focused on promoting of international acceptance of accredited laboratory data and reducing technical barriers to trade, such as the retesting of products on markets of signatories. More information about ILAC-MRA is on www.ilac.org. Signatories of ILAC-MRA are e.g. SNAS (Slovakia), CAI (Czech Republic), PCA (Poland), DakS (Germany) or BMWA (Austria). Up to date list of ILAC-MRA signatories is on <http://ilac.org/ilac-mra-and-signatories/>. FIRES, s.r.o. Batizovce is full member of EGOLF also, more information www.egolf.org.uk.



1. INTRODUCTION

This classification report defines the functional resistance in fire classification assigned to element Power and communication cables of Technokabel S.A. at cable supporting system BAKS in accordance with the procedures given in DIN 4102-12: 1998-11.

Test was carried out according to standard STN 92 0205 and meets requirements of DIN 4102-12: 1998-11. Basic deviation in process and carrying out of test between these standards is in measuring and in control of temperature in the test furnace. According to STN 92 0205, plate thermometers according to EN 1363-1 are used. According to DIN 4102-12: 1998-11, common thermocouples of construction which was used for this measurement till issue of EN 1363-1 are used. Measurement by plate thermometers acc. to EN 1363-1 can be considered as stricter method of temperature control in test furnace in compare with thermocouples used till issue of EN 1363-1. Therefore, it is possible to use results of test according to STN 92 0205 for classification of tested cables according to DIN 4102-12: 1998-11, but not conversely. Identified deviation results in stricter course of test and it can lead to reduced classification of tested cables what is accepted as enhanced security in practice.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The element, Power and communication cables of Technokabel S.A. at cable supporting system BAKS, is defined as a cable supporting system with cables with circuit integrity maintenance classes.

2.2 PRODUCT DESCRIPTION

Product comprise of power and communication halogen free cables of company Technokabel S.A. at cable supporting system of company BAKS – cable trays, mesh trays, ladders with accessories (consoles, brackets, supports, hangers, etc.).

Cable supporting system:

Cable tray KCP/KCOP

Cable tray is made of steel sheet thickness 1,5 mm. Height of side wall is 60 mm and maximum tested width of cable tray is 600 mm. Trays are fixed together by two connectors (LPP/LPOPH60, steel sheet thickness 1,5 mm) with nut bolts (SGKM6x12) on sides and by joint plate (BL/BLO, steel sheet thickness 1,0 mm) with nut bolts (SGKM6x12) on the bottom. Maximum tested loading is 27kg.m⁻¹. Tested trays are KCP/KCOP100H60, KCP/KCOP400H60 and KCP/KCOP600H60.

Cable tray KGJ/KGOJ

Cable tray is made of steel sheet thickness 1,0 mm. Height of side wall is 60 mm and maximum tested width of cable tray is 400 mm. Trays are fixed together by nut bolts (SGKM6x12). Maximum tested loading is 20kg.m⁻¹. Tested tray is KGJ/KGOJ400H60.

Cable tray KFL

Cable tray is made of steel sheet thickness 0,7 mm. Height of side wall is 60 mm and maximum tested width of cable tray is 300 mm. Trays are fixed together by integrated plug-in connectors. Maximum tested loading is 10kg.m⁻¹. Tested tray is KFL300H60.

Cable tray KBJ

Cable tray is made of steel sheet thickness 1,0 mm without perforation. Height of side wall is 60 mm and maximum tested width of cable tray is 400 mm. Trays are fixed together by nut bolts (SGKM6x12). Maximum tested loading is 20kg.m⁻¹. Tested tray is KBJ400H60.

Cable mesh tray KDS/KDSO

Cable mesh tray is made of steel wire Ø 4,0 mm and Ø 4,5 mm. Height of side wall is 60 mm and maximum tested width of cable mesh tray is 600 mm. Mesh trays are fixed together by connectors (USSN/USSO). Maximum tested loading is 28kg.m⁻¹. Tested mesh trays are KDS/KDSO400H60 and KDS/DSO600H60.

**Cable ladder DGOP**

Cable ladder is made of steel sheet thickness 1,5 mm and spacing of transoms is 150 mm. Height of side wall is 60 mm and maximum tested width of cable ladder is 400 mm. Cable ladders are fixed together by two connectors (LDC/LDOCH60) with nut bolts (SGK M8x14) on sides. Maximum tested loading is 20kg.m⁻¹. Tested ladder is DGOP400H60.

Cable ladder DUD

Cable ladder is made of steel sheet thickness 1,2 mm and spacing of transoms is 300 mm. Height of side wall is 60 mm and maximum tested width of cable ladder is 400 mm. Cable ladders are fixed together by two connectors (LDC/LDOCH60) with nut bolts (SGKM8x14) on sides. Maximum tested loading is 20kg.m⁻¹. Tested ladder is DUD400H60.

Cable ladder DUP/DUOP

Cable ladder is made of steel sheet thickness 1,5 mm and spacing of transoms is 300 mm. Height of side wall is 60 mm and maximum tested width of cable ladder is 600 mm. Cable ladders are fixed together by two connectors (LDC/LDOCH60) with nut bolts (SGKM8x14) on sides. Maximum tested loading is 27kg.m⁻¹. Tested ladder is DUP600H60.

Cable clip

Single cable clip UDF is made of steel sheet thickness either 1,2 mm or 2,0 mm. Cable clips are used for fixing of cables directly to wall or ceiling.

Partition PGJ

Partition is made of steel sheet thickness 1,0 mm. Partition is fixed to cable tray or mesh tray by nut bolts (SGK M6x12) or clamping pieces (ZS/ZSO) and is used for separation of cables.

Cover PKJ

Cover is made of steel sheet 1,0 mm thick. Cover is used as a cable protection against damage and is fixed to cable tray by clips (ZAP1).

Support

Support CWP/CWOP40H40 with dimensions (40 x 40) mm is made of bent steel sheet thickness 1,5 mm. Support CWP40H22 with dimensions (40 x 22) mm is made of bent steel sheet thickness 1,5 mm. Support is used for installation of trays or ladders.

Brackets

Bracket (WWS/WWSO) is made of steel sheet thickness 2,0 mm. Tested brackets are WWS/WWSO300 and WWS/WWSO400.

Bracket (WWCT/WWCTO) are made from galvanized steel sheet thickness 3,0 mm and base plate with dimensions (90 x 50 x 8) mm. Brackets are used to gripping trays or ladders to consoles or to wall. Tested brackets were WWCTO100.

Bracket (WU/WUO) is made of adjustable base plate with dimensions (86 x 91,5 x 35) mm and steel sheet thickness 3,0 mm. Tested bracket is WU/WUO400.

Brackets are used to gripping trays or ladders to ceiling or to wall.

Consoles WPCB

Consoles consist of base plate with dimensions (130 x 45 x 5) mm and support with dimensions (50 x 35 x 2) mm. Consoles are used for gripping of brackets to ceiling.

Spacer BR

Spacers BR55 with dimensions (42 x 140) mm are made of steel sheet 1,5 mm thick. Spacers are used as reinforcement in place of fixing of brackets.

Head plate – variable PSUN/PSUNO

Head plate with dimensions (180 x 100 x 45) mm is made of bent steel sheet 2,0 mm thick and is used for adjustable fixing of supports (CW..., CM...) to ceiling.



Individual parts of supporting systems are made of galvanized steel, according to Sendzimir method PN-EN 10-346 and PN-EN ISO 1461 or of stainless steel. Detailed information about used materials are specified in table of clause 4.2.

Cables:

Fire resistant power cables, insulated and sheathed with halogen free compounds, are intended for power supply to fire protection equipment which is to operate in fire conditions (e.g. water pumps in fire extinguishing systems, smoke removing fans).

Fire resistant and halogen free communication cables are intended for installation in alarm, signaling, transmission, sound warning and similar systems, also for data processing systems and for analogue or digital data transmission in industrial electronics and control applications in objects of sharp fire protection requirements, particularly in fire alarm and fire automatic control systems.

Halogen free cables shall be applied in locations where, in case of fire, higher safety for human beings and expensive electronic equipment is required. Functions of the cables are maintained – data are transmitted and power is supplied to equipment which must operate in fire conditions and during fire fighting (e.g. emergency lighting, smoke removing fans). The cables are flame retardant and their smoke emission is low, emitted fumes are non-toxic and non-corrosive. The cables are suitable for indoor and outdoor installations.

Cables used by test:

Power cables:

NHXX FE180 PH90/E90 0.6/1 kV
 (N)HXH FE180 PH90/E90 0.6/1 kV
 (N)HXCH FE180 PH90/E90 0.6/1 kV
 (N)HXCH-J-SERVO FE180 PH90/E90 0.6/1 kV

Communication cables:

HTKSH FE180 PH90/E30-E90 240V
 HTKSHekw FE180 PH90/E30-E90 240V
 HDGs FE180 PH90/E30-E90 300/500 V
 HDGs-W FE180 PH90/E30-E90 300/500 V
 HLGs FE180 PH90/E30-E90 300/500 V
 HLGsekwo FE180 PH90/E30-E90 300/500 V

The length of cables was 5,2 m and 4,0 m from that was exposed to fire.

Cable connection TKM/E90

Connection of cables is realized by producer of cables and is used to restore of damaged/torn cables. Ends of cable conductor are jointed together by copper connector (diameter acc. to cable cross-section) and insulated with mica tapes and with heat-shrink tubes.

More detailed information about product construction is shown in test report [1].

3. TEST REPORTS IN SUPPORT OF CLASSIFICATION

3.1 TEST REPORTS

No.	Name of laboratory	Name of sponsor	Test report No.	Date of the test	Test method
[1]	FIRES, s.r.o., Batizovce, SR	Technokabel S.A., Warszawa, PL	FIRES-FR-015-17-AUNE	26. 01. 2017	STN 92 0205: 2014

[1] Test specimens were conditioned according to EN 1363-1 before the fire resistance test



3.2 TEST RESULTS

No./ Test method	Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
[1] STN 92 0205: 2014	1	2 cables (N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV	15	90 minutes no failure / interruption
	2	2 cables (N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV		90 minutes no failure / interruption
	3	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	4	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV		72 minutes
	5	2 cables (N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	14	90 minutes no failure / interruption
	6	2 cables (N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	7	2 cables NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	8	2 cables NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV		90 minutes no failure / interruption
	9	2 cables (N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV	12	90 minutes no failure / interruption
	10	2 cables (N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV		90 minutes no failure / interruption
	11	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	12	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV		90 minutes no failure / interruption
	13	2 cables (N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	11	90 minutes no failure / interruption
	14	2 cables (N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	15	2 cables NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	16	2 cables NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV		75 minutes
	17	2 cables (N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV	10	53 minutes
	18	2 cables (N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV		32 minutes
	19	6 cables NHXH FE180 PH90/E90 1x240 RM 0.6/1 kV		5 minutes
	20	6 cables NHXH FE180 PH90/E90 1x16 RE 0.6/1 kV		45 minutes
	21	2 cables (N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	9	86 minutes
	22	2 cables (N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	23	6 cables NHXH FE180 PH90/E90 1x240 RM 0.6/1 kV		90 minutes no failure / interruption
	24	6 cables NHXH FE180 PH90/E90 1x16 RE 0.6/1 kV		90 minutes no failure / interruption
	25	2 cables (N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV	8	90 minutes no failure / interruption
	26	2 cables (N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV		78 minutes
	27	6 cables NHXH FE180 PH90/E90 1x240 RM 0.6/1 kV + cable connection TKM/E90-1x240		90 minutes no failure / interruption
	28	6 cables NHXH FE180 PH90/E90 1x16 RE 0.6/1 kV + cable connection TKM/E90-1x16		90 minutes no failure / interruption
	29	2 cables (N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV	16	39 minutes
	30	2 cables (N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV		90 minutes no failure / interruption
	31	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV	7	21 minutes
	32	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV		85 minutes
	33	2 cables NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		6 minutes
	34	2 cables NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV		24 minutes
	35	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV	6	83 minutes
	36	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV		52 minutes
	37	2 cables NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV + cable connection TKM/E90-4x50		82 minutes
	38	2 cables NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV + cable connection TKM/E90-4x1.5		90 minutes no failure / interruption



No./ Test method	Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
[1] STN 92 0205: 2014	39	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV	5	90 minutes no failure / interruption
	40	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV		90 minutes no failure / interruption
	41	2 cables NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV + cable connection TKM/E90-4x50		90 minutes no failure / interruption
	42	2 cables NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV + cable connection TKM/E90-4x1.5		50 minutes
	43	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV	16	90 minutes no failure / interruption
	44	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV		33 minutes
	45	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV	3	90 minutes no failure / interruption
	46	2 cables (N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV		34 minutes
	47	2 cables NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV	2	79 minutes
	48	2 cables NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	1	90 minutes no failure / interruption
	49	2 cables NHXH-J FE180 PH90/E90 4x16 RM 0.6/1 kV		90 minutes no failure / interruption
	52	2 cables HDGs FE180 PH90/E30-E90 2x1 mm ² 300/500 V	15	58 minutes
	53	2 cables HTKSHekw FE180 PH90/E30-E90 1x2x0.8 mm 240 V		55 minutes
	54	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	14	90 minutes no failure / interruption
	55	2 cables HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V		90 minutes no failure / interruption
	56	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	13	39 minutes
	57	2 cables HTKSHekw FE180 PH90/E30-E90 1x2x0.8 mm 240 V		90 minutes no failure / interruption
	58	2 cables HLGsekwzo FE180 PH90/E30-E90 300/500 V 3x1.5		40 minutes
	59	2 cables HDGs FE180 PH90/E30-E90 2x1 mm ² 300/500 V	12	90 minutes no failure / interruption
	60	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	11	90 minutes no failure / interruption
	61	2 cables HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V		90 minutes no failure / interruption
	62	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	7	90 minutes no failure / interruption
	63	2 cables HTKSHekw FE180 PH90/E30-E90 1x2x0.8 mm 240 V		90 minutes no failure / interruption
	64	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	6	90 minutes no failure / interruption
	65	2 cables HTKSHekw FE180 PH90/E30-E90 1x2x0.8 mm 240 V		90 minutes no failure / interruption
66	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	5	68 minutes	
67	2 cables HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V		90 minutes no failure / interruption	
68	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	4	90 minutes no failure / interruption	
69	2 cables HTKSHekw FE180 PH90/E30-E90 1x2x0.8 mm 240 V		90 minutes no failure / interruption	
70	2 cables HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V		90 minutes no failure / interruption	
71	2 cables HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V	3	90 minutes no failure / interruption	
72	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V		90 minutes no failure / interruption	
73	2 cables HDGs FE180 PH90/E30-E90 2x1 mm ² 300/500 V	2	90 minutes no failure / interruption	
74	2 cables HTKSH FE180 PH90/E30-E90 1x2x0.8 mm 240 V	1	90 minutes no failure / interruption	
75	2 cables HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V	16	90 minutes no failure / interruption	

The fire test was terminated in the 94th minute upon request of test sponsor.

Specimens S1 – S49 were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.

Specimens S52 – S75 were tested by one-phase voltage supply 1 x 110V with LED diodes 3V /0,03W.

Circuit breakers with rating 3 A were used.



4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 3.2 of DIN 4102-12: 1998-11.

4.2 CLASSIFICATION

The element, **Power and communication cables of Technokabel S.A. at cable supporting system BAKS**, is classified according to the following combinations of performance parameters and classes as appropriate.

Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable	
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Cable tray KCP/KCOP100H60. Brackets WWCT100 fixed to wall. Loading 5kg.m ⁻¹ . Brackets in spacing of 1500 mm. Tracks No. 1 and 2.	E 90	n x ≥ 1,5-16 mm ² n ≥ 2	
	NHXH-J FE180 PH90/E90 4x16 RM 0.6/1 kV		E 90	E 90 n x > 16 mm ² n ≥ 2	
	NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		E 60	E 60	
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V		E 90	n x 2 x ≥ 0,8 mm n ≥ 1 E 90	
HDGs FE180 PH90/E30-E90 300/500V	HDGs FE180 PH90/E30-E90 2x1mm ² 300/500 V		E 90	n x ≥ 1,0 mm ² n ≥ 2 E 90	
(N)HXCH-J-SERVO FE180 PH90/E90 0,6/1 kV	(N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV		Cable tray KFL300H60. Consoles WPCB, brackets WWS/WWSO300, spacers BR55. Loading 10kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 3.	E 30	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV	E 90		E 30	
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V	E 90		n x 2 x ≥ 0,8 mm n ≥ 1 E 90	
HDGs-W FE180 PH90/E30-E90 300/500V	HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V	E 90		n x ≥ 1,0 mm ² n ≥ 2 E 90	
HDGs-W FE180 PH90/E30-E90 300/500V	HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V	E 90		n x ≥ 1,0 mm ² n ≥ 2 E 90	
HTKSHekw FE180 PH90/E30-E90 240V	HTKSHekw FE180 PH90/E30-E90 1x2x0,8 mm 240 V	Combination of cable tray KGJ/KGOJ400H60 and cable ladder DUP/DUOP400H60. Consoles combined of support CWP40H22 and two threaded rods PGM10 are fixed to ceiling by anchors TRSOM10. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 4.		E 90	n x 2 x ≥ 0,8 mm n ≥ 1 E 90
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V			E 90	n x 2 x ≥ 0,8 mm n ≥ 1 E 90



Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable	
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV + cable connection TKM/E90	Cable tray KGJ/KGOJ400H60. Consoles combined of support CWP/CWOP40H40 and two threaded rods PGM10 are fixed to ceiling by anchors TRSOM10. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 5.	E 30	n x ≥ 1,5 mm ² n ≥ 2	
	NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV + cable connection TKM/E90		E 90	E 30	
(N)HXCH-J-SERVO FE180 PH90/E90 0,6/1 kV	(N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV		E 90	n x ≥ 1,5 mm ² n ≥ 2	
	(N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV		E 90	E 90	
HDGs-W FE180 PH90/E30-E90 300/500V	HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V		E 90	n x ≥ 1,0 mm ² n ≥ 2	
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V		E 60	n x 2 x ≥ 0,8 mm n ≥ 1	
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV + cable connection TKM/E90		Cable ladder DUD400H60. Consoles combined of support CWP/CWOP40H40 and two threaded rods PGM10 are fixed to ceiling by anchors TRSOM10. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 6.	E 90	n x ≥ 1,5 mm ² n ≥ 2
	NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV + cable connection TKM/E90			E 60	E 60
(N)HXCH-J-SERVO FE180 PH90/E90 0,6/1 kV	(N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV			E 60	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV			E 30	E 30
HTKSHekw FE180 PH90/E30-E90 240V	HTKSHekw FE180 PH90/E30-E90 1x2x0,8 mm 240 V	E 90		n x 2 x ≥ 0,8 mm n ≥ 1	
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V	E 90		n x 2 x ≥ 0,8 mm n ≥ 1	
(N)HXCH-J-SERVO FE180 PH90/E90 0,6/1 kV	(N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Cable mesh tray KDS/KDSO400H60. Consoles combined of support CWP/CWOP40H40 and two threaded rods PGM8 are fixed to ceiling by anchors TRSOM8. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 7.		Without classification	Without classification
	(N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV			E 60	
HTKSHekw FE180 PH90/E30-E90 240V	HTKSHekw FE180 PH90/E30-E90 1x2x0,8 mm 240 V			E 90	n x 2 x ≥ 0,8 mm n ≥ 1
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V			E 90	n x 2 x ≥ 0,8 mm n ≥ 1
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 1x16 RM 0.6/1 kV + cable connection TKM/E90		E 90	1 x ≥ 16 mm ²	
	NHXH-J FE180 PH90/E90 1x240 RM 0.6/1 kV + cable connection TKM/E90		E 90	E 90	
(N)HXH FE180 PH90/E90 0,6/1 kV	(N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV		E 60	n x ≥ 1,5 mm ² n ≥ 2	
	(N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		E 60	E 60	



Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 1x16 RM 0.6/1 kV	Cable tray KCP/KCOP600H60. Consoles combined of support CWP/CWOP40H40 and two threaded rods PGM10 are fixed to ceiling by anchors TRSOM10. Loading 27kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 9.	E 90	1 x ≥ 16 mm ²
	NHXH-J FE180 PH90/E90 1x240 RM 0.6/1 kV		E 90	E 90
(N)HXH FE180 PH90/E90 0,6/1 kV	(N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Cable mesh tray KDS/KDSO600H60. Consoles combined of support CWP/CWOP40H40 and two threaded rods PGM8 are fixed to ceiling by anchors TRSOM8. Loading 28kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 10.	E 60	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		E 90	E 60
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 1x16 RM 0.6/1 kV	Cable mesh tray KDS/KDSO600H60. Consoles combined of support CWP/CWOP40H40 and two threaded rods PGM8 are fixed to ceiling by anchors TRSOM8. Loading 28kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 10.	E 30	Without classification
	NHXH-J FE180 PH90/E90 1x240 RM 0.6/1 kV		Without classification	
(N)HXCH FE180 PH90/E90 0,6/1 kV	(N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV	Cable tray KCP/KCOP400H60 E. Consoles combined of variable ceiling hanger PSUN/PSUNO E and support WWP/WWSO400 E. Brackets WWS/WWSO400 E, spacers BR40 E, rod grips UPW E, threaded rods PGM10 E, ceiling hangers WPPG E and anchors PRSOM10/90 E. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Tracks No. 11 and 12.	E 30	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV		E 30	E 30
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Cable tray KCP/KCOP400H60 E. Consoles combined of variable ceiling hanger PSUN/PSUNO E and support WWP/WWSO400 E. Brackets WWS/WWSO400 E, spacers BR40 E, rod grips UPW E, threaded rods PGM10 E, ceiling hangers WPPG E and anchors PRSOM10/90 E. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Tracks No. 11 and 12.	E 60	n x ≥ 1,5 mm ² n ≥ 2
	NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		E 90	E 60
(N)HXH FE180 PH90/E90 0,6/1 kV	(N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Cable tray KCP/KCOP400H60 E. Consoles combined of variable ceiling hanger PSUN/PSUNO E and support WWP/WWSO400 E. Brackets WWS/WWSO400 E, spacers BR40 E, rod grips UPW E, threaded rods PGM10 E, ceiling hangers WPPG E and anchors PRSOM10/90 E. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Tracks No. 11 and 12.	E 90	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		E 90	E 90
(N)HXCH-J-SERVO FE180 PH90/E90 0,6/1 kV	(N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Cable tray KCP/KCOP400H60 E. Consoles combined of variable ceiling hanger PSUN/PSUNO E and support WWP/WWSO400 E. Brackets WWS/WWSO400 E, spacers BR40 E, rod grips UPW E, threaded rods PGM10 E, ceiling hangers WPPG E and anchors PRSOM10/90 E. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Tracks No. 11 and 12.	E 90	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV		E 90	E 90
(N)HXCH FE180 PH90/E90 0,6/1 kV	(N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV	Cable tray KCP/KCOP400H60 E. Consoles combined of variable ceiling hanger PSUN/PSUNO E and support WWP/WWSO400 E. Brackets WWS/WWSO400 E, spacers BR40 E, rod grips UPW E, threaded rods PGM10 E, ceiling hangers WPPG E and anchors PRSOM10/90 E. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Tracks No. 11 and 12.	E 90	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV		E 90	E 90
HDGs-W FE180 PH90/E30-E90 300/500V	HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V		E 90	n x ≥ 1,0 mm ² n ≥ 2 E 90
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V		E 90	n x 2 x ≥ 0,8 mm n ≥ 1 E 90
HDGs FE180 PH90/E30-E90 300/500V	HDGs FE180 PH90/E30-E90 2x1mm ² 300/500 V		E 90	n x ≥ 1,0 mm ² n ≥ 2 E 90
HLGsekwo FE180 PH90/E30-E90 300/500V	HLGsekwo FE180 PH90/E30-E90 300/500 V 3x1.5	Cable tray KBJ400H60. Consoles combined of support CWP40H22 and two threaded rods PGM8 are fixed to ceiling by anchors TRSOM8. Loading 20kg.m ⁻¹ . Consoles in spacing of 1500 mm. Track No. 13.	E 30	n x ≥ 1,5 mm ² n ≥ 3 E 30
HTKSHekw FE180 PH90/E30-E90 240V	HTKSHekw FE180 PH90/E30-E90 1x2x0,8 mm 240 V		E 90	n x 2 x ≥ 0,8 mm n ≥ 1 E 90
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V		E 30	n x 2 x ≥ 0,8 mm n ≥ 1 E 30



Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable	
NHXH FE180 PH90/E90 0,6/1 kV	NHXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Cable ladder DGOP400H60. Brackets WU/WUO400 F, rod grips UPW/UPWKO F, threaded rods PGM10 E, hangers WPPGV/WPPOV F, anchors PRSOM10x80 F. Loading 20kg.m ⁻¹ . Brackets in spacing of 1500 mm. Track No. 14.	E 90	n x ≥ 1,5 mm ² n ≥ 2	
	NHXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		E 90	E 90	
(N)HXH FE180 PH90/E90 0,6/1 kV	(N)HXH-J FE180 PH90/E90 4x1.5 RE 0.6/1 kV		E 90	n x ≥ 1,5 mm ² n ≥ 2	
	(N)HXH-J FE180 PH90/E90 4x50 RM 0.6/1 kV		E 90	E 90	
HDGs-W FE180 PH90/E30-E90 300/500V	HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V		E 90	n x ≥ 1,0 mm ² n ≥ 2	
HTKSH FE180 PH90/E30-E90 240V	HTKSH FE180 PH90/E30-E90 1x2x0,8 mm 240 V		E 90	n x 2 x ≥ 0,8 mm n ≥ 1	
(N)HXCH-J-SERVO FE180 PH90/E90 0,6/1 kV	(N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV		Cable tray KCP/KCOP400H60 F. Brackets WU/WUO400 F, rod grips UPW/UPWKO F, threaded rods PGM10 E, hangers WPPGV/WPPOV F, anchors PRSOM10x80 F. Loading 20kg.m ⁻¹ . Brackets in spacing of 1500 mm. Track No. 15.	E 60	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV			E 90	E 60
(N)HXCH FE180 PH90/E90 0,6/1 kV	(N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV			E 90	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV			E 90	E 90
HTKSHekw FE180 PH90/E30-E90 240V	HTKSHekw FE180 PH90/E30-E90 1x2x0,8 mm 240 V			E 30	n x 2 x ≥ 0,8 mm n ≥ 1
HDGs FE180 PH90/E30-E90 300/500V	HDGs FE180 PH90/E30-E90 2x1mm ² 300/500 V			E 30	n x ≥ 1,0 mm ² n ≥ 2
(N)HXCH-J-SERVO FE180 PH90/E90 0,6/1 kV	(N)HXCH-J-SERVO FE180 PH90/E90 4x1.5 RE 0.6/1 kV	Single cable clips UDF fixed to ceiling in spacing of 600 mm. Track No. 16.		E 30	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH-J-SERVO FE180 PH90/E90 4x50 RM 0.6/1 kV			E 90	E 30
(N)HXCH FE180 PH90/E90 0,6/1 kV	(N)HXCH FE180 PH90/E90 4x1.5/1.5 RE 0.6/1 kV			E 90	n x ≥ 1,5 mm ² n ≥ 2
	(N)HXCH FE180 PH90/E90 4x50/25 RM 0.6/1 kV			E 30	E 30
HDGs-W FE180 PH90/E30-E90 300/500V	HDGs-W FE180 PH90/E30-E90 2x1 mm ² 300/500 V			E 90	n x ≥ 1,0 mm ² n ≥ 2

The element, Power and communication cables of Technokabel S.A. at cable supporting system BAKS with circuit integrity maintenance classes are classified to classes according to achieved test results of tested cables at tracks. Other classification is not allowed.



4.3 FIELD OF APPLICATION

This classification is valid for the following end use applications:

General:

- throughout the period during which circuit integrity is to be maintained, neighbouring building components shall not have a negative effect on circuit integrity;
- although testing is only carried out on cables arranged horizontally, test results also apply to cables arranged either diagonally or vertically (e.g. risers), as long as the cable system is supported in transitional areas (i.e. where it switches from a horizontal to a vertical arrangement) in such a manner that the cables will not slip or kink at corners;
- if the standard support construction specified here is used for testing, test results also apply to other types of tested support construction;
- where risers are used, circuit integrity classification only applies if the cable is effectively supported (i.e. with a spacing of supports of 3500 mm or less). Cables may also be stabilized by a seal at penetrations in floors, provided that the sealant material is of a suitable material class, or using clips of proven suitability. The suitability of any design other than that shown in DIN 4102-12, figure 5 may only be assessed by an accredited test laboratory;
- for vertical systems, the test results obtained for cables mounted singly on the ceiling using single clips apply. In practice, brackets of proven suitability may also be used, as long as their spacing is equal to that of the single clips tested;
- results of testing single cables on the ceiling apply also to cables mounted horizontally on walls;
- results of testing bunched cables on a ladder or tray also apply to support construction attached to a wall as shown in DIN 4102-12, figure 6. However, such constructions require proof of suitability by means of a test certificate or other document issued by an accredited testing laboratory.

5. LIMITATIONS

This classification document does not represent type approval or certification of the product.

The classification is valid provided that the product, field of application and standards and regulations are not changed.

Approved:

Ing. Štefan Rástocký
leader of the testing laboratory

Signed:

Dávid Šubert
technician of the testing laboratory

