

CLASSIFICATION OF FUNCTION IN FIRE FIRES-CR-063-16-AUPE

**Power and communications cables Celina Bitner Zaklady Kablove BITNER,
type – NHXH, NHXCH, (N)HXH, (N)HXCH, JE-H(St)H**

This is an electronic version of a classification report which was made as a copy of classification report officially issued in a paper form. The electronic version of a classification report shall be used only for informative purpose. Any information listed in this classification report is the property of the sponsor and shall not be used or published without written permission. Contents of this file may only be modified by the editor i.e. FIRES, s.r.o., Batizovce. Sponsor is allowed to publish this classification report in parts only with written permission of the editor.



CLASSIFICATION OF FUNCTION IN FIRE IN ACCORDANCE WITH DIN 4102-12: 1998-11 with direct field of application

FIRES-CR-063-16-AUPE

Name of the product: Power and communications cables Celina Bitner Zakłady Kablowe BITNER, type – NHXH, NHXCH, (N)HXH, (N)HXCH, JE-H(St)H

Sponsor: Celina Bitner Zakłady Kablowe BITNER
ul. Józefa Friedleina 3/3
30-009 Kraków
Poland

Prepared by: FIRES, s.r.o.
Osloboditeľov 282
059 35 Batizovce
Slovak Republic

Tested property: Function in fire
Test method: DIN 4102 – 12
Type of test: Accredited

Task No.: PR-16-0147
Date of issue: 23. 03. 2016

Reports: 5
Copy No.: 2

Distribution list:

Copy No. 1 FIRES, s. r. o., Osloboditeľov 282, 059 35 Batizovce, Slovak Republic (electronic version)
Copy No. 2 Celina Bitner Zakłady Kablowe BITNER, ul. Józefa Friedleina 3/3 30-009 Kraków, Poland (electronic version)
Copy No. 3 BAKS Kazimierz Sielski, ul. Jagodne 5, 05-480 Karczew, Poland (electronic version)
Copy No. 4 Celina Bitner Zakłady Kablowe BITNER, ul. Józefa Friedleina 3/3 30-009 Kraków, Poland
Copy No. 5 BAKS Kazimierz Sielski, ul. Jagodne 5, 05-480 Karczew, Poland

This classification report may only be used or reproduced in its entirety.

This report includes accreditation mark SNAS with additional mark ILAC-MRA. SNAS is signatory of ILAC-MRA, Mutual recognition agreement (of accreditation), which is focused on promoting of international acceptance of accredited laboratory data and reducing technical barriers to trade, such as the retesting of products on markets of signatories. More information about ILAC-MRA is on www.ilac.org. Signatories of ILAC-MRA are e.g. SNAS (Slovakia), CAI (Czech Republic), PCA (Poland), DakS (Germany) or BMWA (Austria). Up to date list of ILAC-MRA signatories is on <http://ilac.org/ilac-mra-and-signatories/>. FIRES, s.r.o. Batizovce is full member of EGOLF also, more information www.egolf.org.uk.



1. INTRODUCTION

This classification report defines the function in fire classification assigned to element Power and communications cables Celina Bitner Zakłady Kablowe BITNER, type – NHXH, NHXCH, (N)HXH, (N)HXCH, JE-H(St)H at cable bearing system BAKS in accordance with the procedures given in DIN 4102-12: 1998-11.

This products have already been classified by FIRES, s.r.o. and number of previous classification of function in fire is FIRES-CR-127-07-NUPE, issued on 03. 08. 2007 with validity until 03. 08. 2012.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The element, Power and communications cables Celina Bitner Zakłady Kablowe BITNER, type – NHXH, NHXCH, (N)HXH, (N)HXCH, JE-H(St)H at cable bearing system BAKS, is defined as a power and communication cables with integrity maintenance in case of fire.

2.2 PRODUCT DESCRIPTION

Product comprised from fire resistant halogen free power and communication cables at cable bearing system.

Power cables NHXH, (N)HXH, NHXCH, (N)HXCH - safety cables are used in all locations where a special protection against fire and fire damage is necessary for human life and equipment and where strict safety regulations have to be met and where large emergency running time is necessary. They may be used indoor and outdoor, but not directly in earth and water. They are considered as protectively insulated.

Communication cables JE-H(St)H – safety installations cables are used for transmission od signals and measuring data in control circuits, in locations where a particular protection against fire and fire damage for human life and equipment is necessary. Installation cables are not admissible for power installation purposes and direct burial.

Used cables and cable bearing system by test:

<u>Used cables by test:</u>	NHXH - 4x1,5 RE E90 MICA	(6 x)
	NHXH - 4x50 RM E90 MICA	(8 x)
	(N)HXH - 4x1,5 RE E90 CERAMIC	(10 x)
	NHXCH - 4x1,5 RE/1,5 E90 MICA	(6 x)
	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	(6 x)
	(N)HXCH - 4x10 RE/10 E90 CERAMIC	(2 x)
	NHXCH - 4x50 RM/25 E90 MICA	(6 x)
	JE-H(St)H - 2x2x0,8 E90 MICA	(6 x)
	JE-H(St)H - 2x2x0,8 E90 CERAMIC	(4 x)

Used bearing systems by tests:

Bearing system BAKS – cable trays KCOP, cable ladders DGOP, ceiling ledges SDOC with clips UKO1, clips UDF, UEF and cable holder OZMO with accessories (consoles, booms, hangers, threaded rods, dowels etc.). Producer BAKS Kazimierz Sielski, Poland.

Bearing system Niedax – cable clips SAS with accessories (dowels etc.). Producer Niedax GmbH & Co. KG (Germany).

Bearing system CABLOFIL[®] – cable mesh trays CF with accessories (consoles, booms, hangers, threaded rods, dowels etc.). Producer CABLOFIL[®] (France).

More detailed information about product construction is shown in the drawings which form an integral part of test reports [1]. Drawings were delivered by sponsor.



3. TEST REPORTS IN SUPPORT OF CLASSIFICATION

3.1 TEST REPORTS

No.	Name of laboratory	Name of sponsors	Test report No.	Date of the test	Test method
[1]	Fires s.r.o., Batizovce, SR	Celina Bitner Zaklady Kablowe BITNER Kraków, Poland	FIRES-FR- 129-07-AUNE	12. 07. 2007	DIN 4102 – 12: 1998-11

3.2 TEST RESULTS

Test report No. /Test method	Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
[1] DIN 4102-12	1	(N)HXH - 4x1,5 RE E90 CERAMIC	2	90 minutes no failure / interruption
	2	(N)HXH - 4x1,5 RE E90 CERAMIC	2	90 minutes no failure / interruption
	3	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	2	90 minutes no failure / interruption
	4	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	2	90 minutes no failure / interruption
	5	(N)HXH - 4x1,5 RE E90 CERAMIC	1	90 minutes no failure / interruption
	6	(N)HXH - 4x1,5 RE E90 CERAMIC	1	90 minutes no failure / interruption
	7	(N)HXCH - 4x10 RE/10 E90 CERAMIC	3	90 minutes no failure / interruption
	8	(N)HXCH - 4x10 RE/10 E90 CERAMIC	3	90 minutes no failure / interruption
	9	(N)HXH - 4x1,5 RE E90 CERAMIC	3	79 minutes
	10	(N)HXH - 4x1,5 RE E90 CERAMIC	3	90 minutes no failure / interruption
	11	(N)HXH - 4x1,5 RE E90 CERAMIC	4	90 minutes no failure / interruption
	12	(N)HXH - 4x1,5 RE E90 CERAMIC	4	90 minutes no failure / interruption
	13	(N)HXH - 4x1,5 RE E90 CERAMIC	5	90 minutes no failure / interruption
	14	(N)HXH - 4x1,5 RE E90 CERAMIC	5	90 minutes no failure / interruption
	15	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	5	76 minutes
	16	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	5	90 minutes no failure / interruption
	17	NHXH - 4x50 RM E90 MICA	6	90 minutes no failure / interruption
	18	NHXH - 4x50 RM E90 MICA	6	41 minutes
	19	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	6	71 minutes
	20	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	6	90 minutes no failure / interruption
	21	NHXH - 4x1,5 RE E90 MICA	7	90 minutes no failure / interruption
	22	NHXH - 4x1,5 RE E90 MICA	7	90 minutes no failure / interruption
	23	NHXH - 4x50 RM E90 MICA	8	83 minutes
	24	NHXH - 4x50 RM E90 MICA	8	76 minutes
	25	NHXCH - 4x1,5 RE/1,5 E90 MICA	10	90 minutes no failure / interruption
	26	NHXCH - 4x1,5 RE/1,5 E90 MICA	10	90 minutes no failure / interruption
	27	NHXCH - 4x50 RM/25 E90 MICA	11	90 minutes no failure / interruption
	28	NHXCH - 4x50 RM/25 E90 MICA	11	90 minutes no failure / interruption
	29	NHXCH - 4x1,5 RE/1,5 E90 MICA	12	90 minutes no failure / interruption
	30	NHXCH - 4x1,5 RE/1,5 E90 MICA	12	90 minutes no failure / interruption
	31	NHXCH - 4x50 RM/25 E90 MICA	12	90 minutes no failure / interruption
	32	NHXCH - 4x50 RM/25 E90 MICA	12	90 minutes no failure / interruption
	33	NHXCH - 4x1,5 RE/1,5 E90 MICA	13	90 minutes no failure / interruption
	34	NHXCH - 4x1,5 RE/1,5 E90 MICA	13	90 minutes no failure / interruption
	35	NHXCH - 4x50 RM/25 E90 MICA	13	90 minutes no failure / interruption
	36	NHXCH - 4x50 RM/25 E90 MICA	13	90 minutes no failure / interruption
	37	NHXH - 4x1,5 RE E90 MICA	14	90 minutes no failure / interruption
	38	NHXH - 4x1,5 RE E90 MICA	14	90 minutes no failure / interruption
	39	NHXH - 4x50 RM E90 MICA	14	90 minutes no failure / interruption
	40	NHXH - 4x50 RM E90 MICA	14	90 minutes no failure / interruption
	41	NHXH - 4x1,5 RE E90 MICA	15	46 minutes
	42	NHXH - 4x1,5 RE E90 MICA	15	45 minutes
	43	NHXH - 4x50 RM E90 MICA	15	90 minutes no failure / interruption
	44	NHXH - 4x50 RM E90 MICA	15	90 minutes no failure / interruption



Test report No. /Test method	Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
[1] DIN 4102-12	52	JE-H(St)H - 2x2x0,8 E90 CERAMIC	5	77 minutes
	53	JE-H(St)H - 2x2x0,8 E90 CERAMIC	5	30 minutes
	54	JE-H(St)H - 2x2x0,8 E90 CERAMIC	6	87 minutes
	55	JE-H(St)H - 2x2x0,8 E90 CERAMIC	6	39 minutes
	56	JE-H(St)H - 2x2x0,8 E90 MICA	9	90 minutes no failure / interruption
	57	JE-H(St)H - 2x2x0,8 E90 MICA	9	90 minutes no failure / interruption
	58	JE-H(St)H - 2x2x0,8 E90 MICA	16	90 minutes no failure / interruption
	59	JE-H(St)H - 2x2x0,8 E90 MICA	16	88 minutes
	60	JE-H(St)H - 2x2x0,8 E90 MICA	17	79 minutes
	61	JE-H(St)H - 2x2x0,8 E90 MICA	17	90 minutes no failure / interruption

[1] The test was discontinued in 92nd minute at the request of test sponsor.

Specimens S1 – S44 were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Specimens S52 – S61 were tested by one-phase voltage supply 1 x 110V with LED diodes 3V /0,03W. Circuit breakers with rating 3 A were used.

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 3.2 of DIN 4102 – 12: 1998-11.

4.2 CLASSIFICATION

The element, Power and communications cables Celina Bitner Zakłady Kablowe BITNER, type – NHXH, NHXCH, (N)HXH, (N)HXCH, JE-H(St)H at cable bearing system is classified according to the following combinations of performance parameters and classes as appropriate.

Used cables by test [1] are classified as follows:

Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable
(N)HXH E90 CERAMIC	(N)HXH - 4x1,5 RE E90 CERAMIC	Cable bearing system BAKS. Cable trays KCOP 300H60/3N. Consoles WPCO 800 fixed by two dowels PSRO M10x80. Booms WMCO 400 with holders UPWO and threaded rods PGM10 with holders USOV. Consoles in spacing of 1200 mm. Loading 10 kg.m ⁻¹ . Track No. 1.	E 90	Without classification
(N)HXH E90 CERAMIC	(N)HXH - 4x1,5 RE E90 CERAMIC	Cable bearing system BAKS. Cable ladders DGOP 400H60/3N. Consoles WPCO 800 fixed by two dowels PSRO M10x80. Booms WMCO 400 with holders UPWO and threaded rods PGM10 with holders USOV. Consoles in spacing of 1200 mm. Loading 20 kg.m ⁻¹ . Track No. 2.	E 90	Without classification
(N)HXCH E90 CERAMIC	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC		E 90	
(N)HXH E90 CERAMIC	(N)HXH - 4x1,5 RE E90 CERAMIC	Cable bearing system BAKS. Cable clips UEF fixed by dowels SRO M6x30. Clips in spacing of 300 mm. Ceiling mounting. Track No. 3.	E 60	Without classification
(N)HXCH E90 CERAMIC	(N)HXCH - 4x10 RE/10 E90 CERAMIC		E 90	Without classification



Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable
(N)HXH E90 CERAMIC	(N)HXH - 4x1,5 RE E90 CERAMIC	Cable bearing system BAKS. Cable clips UDF fixed by dowels SRO M6x30. Clips in spacing of 300 mm. Ceiling mounting. Track No. 4.	E 90	Without classification
(N)HXH E90 CERAMIC	(N)HXH - 4x1,5 RE E90 CERAMIC	Cable bearing system BAKS. Cable holders OZMO Holders fixed by dowels SRO M6x30. Holders in spacing of 300 mm. Ceiling mounting. Track No. 5.	E 90	Without classification
(N)HXCH E90 CERAMIC	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC		E 60	Without classification
JE-H(St)H E90 CERAMIC	JE-H(St)H - 2x2x0,8 E90 CERAMIC		E 30	n x 2 x ≥ 0,8 mm n ≥ 2 E 30
(N)HXCH E90 CERAMIC	(N)HXCH - 4x1,5 RE/1,5 E90 CERAMIC	Cable bearing system BAKS. Cable clips UKO1 in the ledges SDOC 600. Ledges fixed by dowels PSRO M8x75. Clips and ledges in spacing of 300 mm. Ceiling mounting. Track No. 6.	E 60	Without classification
NHXH E90 MICA	NHXH - 4x50 RM E90 MICA		E 30	Without classification
JE-H(St)H E90 CERAMIC	JE-H(St)H - 2x2x0,8 E90 CERAMIC		E 30	n x 2 x ≥ 0,8 mm n ≥ 2 E 30
NHXH E90 MICA	NHXH - 4x1,5 RE E90 MICA	Cable bearing system Niedax. Clips SAS. Clips fixed by dowels DAM M6x50. Clips in spacing of 300 mm. Ceiling mounting. Track No. 7, 8, 9, 10 and 11.	E 90	n x ≥ 1,5 mm ² n ≥ 2 E 60
	NHXH - 4x50 RM E90 MICA		E 60	
JE-H(St)H E90 MICA	JE-H(St)H - 2x2x0,8 E90 MICA		E 90	n x 2 x ≥ 0,8 mm n ≥ 2 E 90
NHXCH E90 MICA	(N)HXCH - 4x1,5 RE/1,5 E90 MICA		E 90	n x ≥ 1,5/1,5 mm ² n ≥ 2 E 90
	NHXCH - 4x50 RM/25 E90 MICA		E 90	
NHXCH E90 MICA	(N)HXCH - 4x1,5 RE/1,5 E90 MICA	Cable bearing system CABLOFIL. Cable mesh trays CF54/300. Consoles combined of supporting profiles R21S400 and two threaded rods M10. Consoles in spacing of 1200 mm. Loading 20 kg.m ⁻¹ . Track No. 12 and 14.	E 90	n x ≥ 1,5/1,5 mm ² n ≥ 2 E 90
	NHXCH - 4x50 RM/25 E90 MICA		E 90	
NHXH E90 MICA	NHXH - 4x1,5 RE E90 MICA		E 90	n x ≥ 1,5 mm ² n ≥ 2 E 90
	NHXH - 4x50 RM E90 MICA		E 90	



Cable	Type of tested cable, single cross-sections and number of conductors	Arrangement	Classification for type of tested cable (by cross-sections and number of conductors)	Classification for cable
NHXCH E90 MICA	(N)HXCH - 4x1,5 RE/1,5 E90 MICA	Cable bearing system CABLOFIL. Cable mesh trays CF105/300. Consoles R41S1000 with holder PFN41S fixed by two dowels HKD-S10x40. Booms CU400 with threaded rods M8. Consoles in spacing of 1200 mm. Loading 20 kg.m ⁻¹ . Track No. 13.	E 90	n x ≥ 1,5/1,5 mm ² n ≥ 2 E 90
	NHXCH - 4x50 RM/25 E90 MICA		E 90	
NHXH E90 MICA	NHXH - 4x1,5 RE E90 MICA	Cable bearing system CABLOFIL. Cable mesh trays CF105/300. Consoles R41S1000 with holder PFN41S fixed by two dowels HKD-S10x40. Booms C21S400 with threaded rods M8. Consoles in spacing of 1200 mm. Loading 20 kg.m ⁻¹ . Track No. 15.	E 30	n x ≥ 1,5 mm ² n ≥ 2 E 30
	NHXH - 4x50 RM E90 MICA		E 90	
JE-H(St)H E90 MICA	JE-H(St)H - 2x2x0,8 E90 MICA	Cable bearing system CABLOFIL. Cable mesh trays CF54/50. Consoles combined of two hangers CEQ100 and threaded rods M8 fixed to dowels HKD-S8x40. Consoles in spacing of 1200 mm. Loading 5 kg.m ⁻¹ . Track No. 16.	E 60	n x 2 x ≥ 0,8 mm n ≥ 2 E 60
JE-H(St)H E90 MICA	JE-H(St)H - 2x2x0,8 E90 MICA	Cable bearing system CABLOFIL. Cable mesh trays CF54/100. Consoles R41S1000 with holder PFN41S fixed by two dowels HKD-S10x40. Booms CU100 with threaded rods M8. Consoles in spacing of 1200 mm. Loading 10 kg.m ⁻¹ . Track No. 17.	E 60	n x 2 x ≥ 0,8 mm n ≥ 2 E 60

The element, Power and communications cables Celina Bitner Zakłady Kablowe BITNER, type – NHXH, NHXCH, (N)HXH, (N)HXCH, JE-H(St)H at cable bearing system are classified to classes according to achieved test results of tested cables at tracks. Other classification is not allowed.



4.3 FIELD OF APPLICATION

This classification is valid for the following end use applications:

- § throughout the period during which circuit integrity is to be maintained, neighbouring building components shall not have a negative effect on circuit integrity;
- § classification for type of cable (by cross-sections and number of conductors) is valid only for tested cable types, number and cross-sections of conductors;
- § classification for cable is valid for all numbers and cross-sections of tested cable type;
- § although testing is only carried out on cables arranged horizontally, test results also apply to cables arranged either diagonally or vertically (e.g. risers), as long as the cable system is supported in transitional areas (i.e. where it switches from a horizontal to a vertical arrangement) in such a manner that the cables will not slip or kink at corners;
- § test results of function in fire test of cables tested at standard supporting construction are also applicable for tested standard supporting construction of other producers;
- § test results of function in fire test of cables tested at standard supporting construction are also applicable for cables of other producers tested at standard supporting construction;
- § test results of function in fire test of cables at nonstandard supporting construction are valid only for tested construction with particular tested cable type and are also applicable for supporting construction with smaller spacing of consoles and smaller loading;
- § test results of cables tested in cable trays or ladders are applicable also for cable trays and ladders with particular construction with smaller width as tested with particular smaller loading;
- § test results of cables tested at cable trays or ladders are applicable also for another products trays and ladders (cross, elbow, T-bend, bends and etc.);
- § maximal length of increasing routing shall be 3500 mm with consistent horizontal placing of cable with minimal length of 300 mm (apart from cable bending) and with maximal spacing of clips of 300 mm, eventually the cables are stabilized by cable transmissions at floor or ceiling with particular fire resistance;
- § for vertical systems, the test results obtained for cables mounted singly on the ceiling using single clips apply. Brackets of proven suitability may also be used, as long as their spacing is equal to that of the single clips tested;
- § results of testing single cables on the ceiling apply also to cables mounted horizontally on walls;
- § results of testing bunched cables on a ladder or tray also apply to support construction attached to a wall. However, such constructions required proof of suitability by means of a test certificate or other document issued by an accredited testing laboratory;
- § test results are applicable only for systems without connection elements (e.g. junction box, branch bar).

5. LIMITATIONS

Load-bearing construction elements for fixing of cable systems must be proved for at least the same fire resistance compare to classified function in fire of cable system.

The construction contractor is solely responsible for proper preparation.

This classification document does not represent type approval or certification of the product.

The classification is valid provided that the product, field of application and standards and regulations are not changed.

Approved:

Ing. Štefan Rástocký
leader of the testing laboratory



Signed:

Miroslav Hudák
technician of the testing laboratory