

TEST REPORT FIRES-FR-234-07-AUNE

Cable bearing system BAKS



This is an electronic version of a test report which was made as a copy of test report officially issued in a paper form. The electronic version of a test report shall be used only for informative purposes. Any information listed in this test report is the property of the sponsor and shall not be used or published without written permission. Contents of this file may only be modified by the editor i.e. Testing laboratory FIRES s.r.o. Batizovce. Sponsor is allowed to publish this test report in parts only with written permission of the editor.

FIRES, s.r.o.

Notifikovaná osoba č./ Notified Body No.: 1396

Autorizovaná osoba reg. č./Approved Body No.: SK01

Osloboditeľov 282, 059 35 Batizovce, Slovakia

Tel.+421 52 775 2298, Fax+421 52 7881412, e-mail: info@fires.sk, www.fires.sk

Reg. No. 041/S-159

Testing laboratory No. 041/S-159 accredited by
Slovak national accreditation service

TEST REPORT

Test report number: **FIRES-FR-234-07-AUNE**

Tested property: Function in fire

Test method: DIN 4102 – 12:1998-11

Date of issue: **07. 01. 2008**

Name of the product: Cable bearing system BAKS

Manufacturer: **BAKS Kazimierz Sielski**, ul. Jagodne 5,
05-480 Karczew, Poland - producer of construction**Zakłady Kablowe Bitner Celina Bitner**, Friedleina 3/3,
30-009 Kraków, Poland – producer of cablesSponsor: **BAKS Kazimierz Sielski**, ul. Jagodne 5, 05-480 Karczew, Poland

Task No.: PR-07-0423

Specimen received: 10. 12. 2007

Date of the fire test: 13. 12. 2007

Technician responsible for the technical side of this report: Miroslav Hudák

Number of pages: 6

Number of appendices: 25

Test reports: 3

Copy No.: 2

Distribution list:

Copy No.1: **FIRES, s.r.o.**, Osloboditeľov 282, SK-059 35 Batizovce, Slovakia
(electronic version)Copy No.2: **BAKS Kazimierz Sielski**, ul. Jagodne 5, 05-480 Karczew, Poland
(electronic version)Copy No.3: **BAKS Kazimierz Sielski**, ul. Jagodne 5, 05-480 Karczew, Poland

1. INTRODUCTION

This test report contains the results of the test carried out at the testing laboratory of FIRES s.r.o. in Batizovce. The purpose of the test was product classification. The test specimen was power and communication non-halogen cables with circuit integrity maintenance. Persons witnessing the test:

Representatives of the sponsor: Mr. Jacek Kliczek (BAKS)
 Mr. Adam Cichoń (Zakłady Kablowe Bitner)
 Mr. Jan Krajewski (Zakłady Kablowe Bitner)

Test directed by: Mr. Štefan Rástocký
 Test carried out by: Mr. Miroslav Hudák
 Operator: Mr. Alexander Rel'ovský

2. MEASURING EQUIPMENT

Identification number	Measuring equipment	Note
F 90 002	Horizontal test furnace for fire testing	-
F 69 005	PLC system for data acquisition and control TECOMAT NS 950	-
F 40 008	Software Control Web 2000	
F 40 009	Control and communication software to PLC TECOMAT NS 950	
F 40 010	Visual and calculating software to PLC TECOMAT NS 950	-
F 40 011	Driver Tecomat – CW 2000 (software)	-
F 71 008, F 71 009	Transducer of differential pressure (from -50 to +150) Pa	pressure inside the test furnace
F 06 501, F 06 502, F 06 503, F 06 504 F 06 505, F 06 506, F 06 507, F 06 508	Plate thermometers	temperature inside the test furnace, according to EN 1363-1 a DIN 4102-2
F 06 701	Sheathed thermocouple type K ϕ 3 mm	ambient temperature
F 69 009	PLC system for data acquisition and climate control TECOMAT TC 604	climatic conditions
F 60 001 – F 60 009	Temperature and relative air humidity sensors	climatic conditions
F 54 057	Racking meter	-
F 57 007	Digital stop-watch	-
F 96 015	Test signal panel	-

3. PREPARATION OF THE SPECIMEN

Testing laboratory didn't take off individual components of the specimen. Components take-off and its delivering to the testing laboratory were carried out by the test sponsor. Assembling of the supporting system into the test furnace was carried out by workers of the test sponsor. Mounting of cables and weights into the supporting system was carried out by workers businesses BAKS and Zakłady Kablowe Bitner.

4. PREPARATION OF THE TEST

4.1 DESCRIPTION OF THE SPECIMEN STRUCTURE

Test specimen comprised from cable bearing systems BAKS with accessories – basket cable trays, ceiling ledges with clips UKO1, clips KSA, sleeves OZMO and power and communication non-halogen cables business Zakłady Kablowe Bitner.

Cables:	NHXXH 4x1,5 RE FE180/E90 MICA	(6 x)
	NHXXH 5x10 RE FE180/E90 MICA	(2 x)
	NHXXH 4x50 RM FE180/E90 MICA	(6 x)
	NHXXCH 4x1,5 RE/1,5 FE180/E90 MICA	(6 x)
	NHXXCH 4x10 RE/10 FE180/E90 MICA	(2 x)
	NHXXCH 4x50 RM/25 FE180/E90 MICA	(4 x)
	(N)HXXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC	(4 x)
	JE-H(St)H 2x2x0,8 FE180/E90 MICA	(10 x)
	JE-H(St)H 2x2x0,8 FE180/E90 CERAMIC	(4 x)
	HTKSH(ekw) 1x2x1,0 PH90	(6 x)

Ceiling installation: was made by ceiling ledges (type SDOC 600) which were fixed to ceiling by three dowels (type PRSO M8x75) in spacing of 300 mm. Cables were fixed to ledges by clips (type UKO1) in spacing of 300 mm and by cable clips (type KSA) depending on the diameter of cable which were fixed to ceiling by dowels (type SRO M6x30, TRSO M6x30, threaded bar M6x100) in spacing of 600 mm and sleeves OZMO, which were fixed to ceiling by dowels (type SRO M6x30) in spacing of 300 mm. Sleeves OZMO were loaded with 1 kg/m.

Suspension track No. 1: was made of three consoles combined of two horizontal supports (type CWOP40H40/05) and two threaded bar M8x600 with washers and nuts M8 and two hangers (type USOV) which were fixed to ceiling by dowels (type PRSO M8x75) in spacing of 1200 mm. Basket cable trays (type KDSO400H60) were fixed to horizontal supports. Load-bearing system was loaded with 20 kg/m.

Suspension track No. 2: was made of three consoles combined of horizontal support (type CWOP40H40/05) and two threaded bar M8x300 with washers and nuts M8 and two hangers (type ZK8) which were fixed to steel profiles I 80. These profiles were fixed to ceiling by four dowels (type PRSO M8x75) in spacing of 1200 mm. Basket cable trays (type KDSO400H60) were fixed to horizontal supports. Load-bearing system was loaded with 20 kg/m.

Suspension track No. 3 and 4: was made of three consoles (type WKSO60) which were fixed to ceiling by dowels (type SRO M6x30) in spacing of 1200 mm. Basket cable trays (type KDSO60H60) were fixed to consoles. Load-bearing system was loaded with 1,5 kg/m.

Types of individual components are from catalogue BAKS 8/2006.

Cable penetration through the wall of test furnace was sealed by mineral wool Rockwool.

Loading with steel chain were used as the equivalent load.

More detailed information about specimen construction is shown in the drawings which form the appendix of this test report. Drawings were delivered by the sponsor of the test.

All the information about technical specifications of used materials and semi-products, information about their type sign and their producers were delivered by sponsor. This information was not subject of the specimen inspection. Parameters which were checked are quoted in paragraph 4.3 SPECIMEN INSPECTION.

4.2 DESCRIPTION OF THE SPECIMEN FIXATION

The test specimen was fixed on the ceiling of the test furnace which was created from concrete panels made of common shocked concrete of class B 20, 150 mm thick.

The type of specimen fixation into the test furnace is visible in drawing documentation and it was selected by the sponsor.

4.3 SPECIMEN INSPECTION

Before and after the fire testing, conformity of the test specimen with drawing was checked. The specimen corresponded to the drawing which create appendix of this report.

Specimen inspection consisted of visual review of the test specimen as well as size verification (number and cross sections of conductors, thickness, measurements of cables and trays).

4.4 CLIMATIC CONDITIONING

Test specimens were stored in the climatic hall and conditioned according to EN 1363-1 under the following climatic conditions:

Relative air humidity [%]		Ambient air temperature [°C]	
mean	standard deviation	mean	standard deviation
48,2	2,7	23,0	0,4

The equilibrium state of test specimen humidity was not determined. The test specimen did not comprise hygroscopic material.

5. CARRYING OUT THE TEST

5.1 TEST CONDITIONS

Conditions in the test furnace (temperature, pressure, content O₂ content) as well as conditions in the testing room (ambient temperature) corresponded to EN 1363-1 and DIN 4102-2 during the whole test. Detailed information is shown in appendices of this report or in quality records of the testing laboratory.

Values characterising environment in the testing room directly before the test:

Date of fire test	Relative air humidity [%]	Ambient air temperature [°C]
13. 12. 2007	30,1	10,7

5.2 TEST RESULTS

The measured values are shown in tables that form an integral part of this test report.

5.3 EVALUATION OF THE TEST

SPECIMENS		Time to first failure/interruption of conductor
Specimens 1, 2: cables NHXH 4x1,5 RE FE180/E90 MICA		90 minutes no failure/interruption
Specimens 3, 4: cables NHXH 4x50 RM FE180/E90 MICA		90 minutes no failure/interruption
Specimens 5, 6: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA		90 minutes no failure/interruption
Specimens 7, 8: cables NHXCH 4x50 RM/25 FE180/E90 MICA		90 minutes no failure/interruption
Specimen 9: cable NHXCH 4x10 RE/10 FE180/E90 MICA		90 minutes no failure/interruption
Specimen 10: cable NHXCH 4x1,5 RE/1,5 FE180/E90 MICA		90 minutes no failure/interruption
Specimen 11: cable NHXH 5x10 RE FE180/E90 MICA		90 minutes no failure/interruption
Specimen 12: cable NHXH 4x1,5 RE FE180/E90 MICA		90 minutes no failure/interruption
Specimen 13: cable NHXH 5x10 RE FE180/E90 MICA		90 minutes no failure/interruption
Specimen 14: cable NHXH 4x1,5 RE FE180/E90 MICA		90 minutes no failure/interruption
Specimen 15: cable NHXCH 4x10 RE/10 FE180/E90 MICA		90 minutes no failure/interruption
Specimen 16: cable NHXCH 4x1,5 RE/1,5 FE180/E90 MICA		70 minutes
Specimens 17, 18: cables NHXH 4x1,5 RE FE180/E90 MICA		90 minutes no failure/interruption
Specimens 19, 20: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA		90 minutes no failure/interruption
Specimens 21, 22: cables NHXCH 4x50 RM/25 FE180/E90 MICA		90 minutes no failure/interruption
Specimens 23, 24: cables NHXH 4x50 RM FE180/E90 MICA		90 minutes no failure/interruption
Specimens 25, 26: cables NHXH 4x50 RM FE180/E90 MICA		90 minutes no failure/interruption
Specimen 27: cable (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC		64 minutes
Specimen 28: cable (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC		69 minutes
Specimen 29: cable (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC		61 minutes
Specimen 30: cable (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC		58 minutes
Specimens 52A:	bundle of six cables HTKSH(ekw) - 1x2x1,0 PH90	61 minutes
Specimens 52B:		90 minutes no failure/interruption
Specimens 53A:		41 minutes
Specimens 53B:		61 minutes
Specimens 54A:		63 minutes
Specimens 54B:		58 minutes
Specimens 55, 56, 57, 58, 59, 60:	bundle of six cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA	90 minutes no failure/interruption
Specimens 61, 62: cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA		90 minutes no failure/interruption
Specimens 63, 64: cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA		90 minutes no failure/interruption
Specimen 65: cable JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC		90 minutes no failure/interruption
Specimen 66: cable JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC		75 minutes
Specimen 67: cable JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC		51 minutes
Specimen 68: cable JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC		87 minutes

The fire test was discontinued in 93rd minute at the request of sponsor.

Specimens S1 – S30 were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
Specimens S52 – S68 were tested by one-phase voltage supply 1 x 110V with LED diodes 3V /0,03W.

6. CLOSING


- This report details the method of construction, the test conditions and results obtained when the specific element of construction described herein was following the procedure outlined in EN 1363-1 and DIN 4102 – 12:1998-11. Any significant deviation with respect to size, constructional details, loads, stresses, edges or end conditions other than those allowed under the field of direct application in the relevant test method is not covered by this report.
- Because of the nature of the fire resistance testing and consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.
- The test results refer only to the tested subjects. This test report is not an approval of the tested product by the test laboratory or the accreditation body overseeing the laboratory's activities. The test was carried out on testing equipment that is the property of FIRES Ltd. Without the written permission of the test laboratory this test report may be copied and/or distributed only as the whole. Any modifications of the test report can be made only by the fire resistance test laboratory FIRES Ltd. Batizovce.

Report checked by: Ing. Štefan Rástocký


Translated by: Ing. Marek Rusnák

Issued by:

Responsible for the technical side of this report:


Ing. Štefan Rástocký
leader of the testing laboratory




Miroslav Hudák
technician of the testing laboratory

7. NORMATIVE REFERENCES

DIN 4102 – 2:1977-09	Fire behaviour of building materials and elements - requirements and testing
DIN 4102 – 12:1998-11	Fire resistance of electric cable systems required to maintain circuit integrity
STN EN 1363-1:2001	Fire resistance tests – Part 1: General requirements

8. LIST OF APPENDICES


Appendix 1	Measured values inside the test furnace
Appendix 2	Measured values inside the test furnace / graph
Appendix 3	Measured times of tested specimens from S1 to S8
Appendix 4	Measured times of tested specimens from S9 to S16
Appendix 5	Measured times of tested specimens from S17 to S24
Appendix 6	Measured times of tested specimens from S25 to S30
Appendix 7	Measured times of tested specimens from S52 to S60
Appendix 8	Measured times of tested specimens from S61 to S68
Appendix 9	Layout of cables in the test furnace
Appendix 10-11	Photos taken before and after the fire test
Appendix 12- 25	Drawings

Measured values inside the test furnace




Time t [min]	Temperature [°C]											Deviation d _e [%]	Pressure p [Pa]
	Td1	Td2	Td3	Td4	Td5	Td6	Td7	Td8	Tave	Tn	To		
0	48,9	37,7	43,3	43,1	30,3	44,7	25,6	40,0	39,2	20,0	10,6	0,0	0,0
5	619,0	616,1	619,0	539,9	577,2	617,5	485,5	582,0	582,0	576,4	11,1	-0,1	14,5
10	713,7	704,9	700,8	643,0	697,2	698,4	592,8	664,1	676,9	678,3	11,7	1,6	16,2
15	773,3	762,6	748,8	686,5	767,3	746,7	639,1	713,2	729,7	738,5	11,6	0,5	15,6
20	803,0	802,7	798,2	752,2	785,2	791,0	697,1	762,2	774,0	781,3	11,4	0,1	16,5
25	780,2	786,6	785,6	755,5	792,1	805,0	726,9	764,9	774,6	814,6	11,5	-0,6	16,3
30	812,2	818,9	821,4	802,5	834,3	841,5	777,5	811,9	815,0	841,8	11,3	-1,5	15,9
35	819,7	820,7	825,2	813,8	852,0	853,3	810,9	820,1	827,0	864,8	11,0	-2,0	16,1
40	865,8	865,1	861,9	844,6	885,8	878,7	820,9	841,9	858,1	884,7	11,2	-2,2	16,5
45	886,8	889,1	893,8	858,2	902,9	905,9	839,2	865,9	880,2	902,3	11,1	-2,4	16,3
50	927,0	930,3	933,6	901,1	935,9	945,9	881,6	909,7	920,6	918,1	11,1	-2,1	16,6
55	949,3	949,9	952,4	921,5	956,7	962,9	903,9	928,5	940,6	932,3	11,3	-1,8	16,4
60	961,5	964,5	967,9	939,5	971,2	978,7	923,9	946,0	956,7	945,3	10,8	-1,6	16,6
65	970,2	971,3	965,0	935,1	988,5	973,6	914,4	940,1	957,3	957,3	11,0	-1,4	16,6
70	978,5	979,8	974,1	945,1	994,7	978,3	922,3	949,6	965,3	968,4	11,0	-1,3	16,7
75	989,7	990,9	984,4	952,4	1002,0	988,5	932,3	960,0	975,0	978,7	11,0	-1,2	16,3
80	997,1	996,8	990,7	963,0	1011,0	998,0	943,1	967,5	983,4	988,4	10,9	-1,2	17,1
85	1006,0	1007,0	1002,0	973,5	1018,0	1005,0	953,8	979,7	993,1	997,4	10,9	-1,1	17,3
90	1005,0	1007,0	1005,0	986,0	1026,0	1019,0	988,5	995,6	1004,0	1005,9	11,0	-1,1	16,7
91	1011,0	1012,0	1009,0	989,1	1029,0	1023,0	984,0	997,8	1006,9	1007,6	10,9	-1,1	17,2
92	1012,0	1013,0	1010,0	990,0	1030,0	1025,0	987,0	998,6	1008,2	1009,2	10,9	-1,0	17,3

- Tave** Average temperature in the test furnace calculated from plate thermometers
Tn Standard temperature in the test furnace laid down to test guideline
To Ambient temperature
d_e Deviation of the average temperature from the standard temperature calculated according to test guideline
p Pressure inside the test furnace measured under the ceiling of the test furnace

Layout of measuring points in the test furnace:



Measured values inside the test furnace / graph



Measured time of tested specimens from S1 to S8

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S1	1-L1	no failure / interruption
	2-L2	no failure / interruption
	3-L3	no failure / interruption
	4-PEN	no failure / interruption
S2	5-L1	no failure / interruption
	6-L2	no failure / interruption
	7-L3	no failure / interruption
	8-PEN	no failure / interruption
S3	9-L1	no failure / interruption
	10-L2	no failure / interruption
	11-L3	no failure / interruption
	12-PEN	no failure / interruption
S4	13-L1	no failure / interruption
	14-L2	no failure / interruption
	15-L3	no failure / interruption
	16-PEN	no failure / interruption
S5	17-L1	no failure / interruption
	18-L2	no failure / interruption
	19-L3	no failure / interruption
	20-PEN	no failure / interruption
S6	21-L1	no failure / interruption
	22-L2	no failure / interruption
	23-L3	no failure / interruption
	24-PEN	no failure / interruption
S7	25-L1	no failure / interruption
	26-L2	no failure / interruption
	27-L3	no failure / interruption
	28-PEN	no failure / interruption
S8	29-L1	no failure / interruption
	30-L2	no failure / interruption
	31-L3	no failure / interruption
	32-PEN	no failure / interruption

Specimens 1,2: cables NHXH 4x1,5 RE FE180/E90 MICA
Specimens 3,4: cables NHXH 4x50 RM FE180/E90 MICA
Specimens 5,6: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA
Specimens 7,8: cables NHXCH 4x50 RM/25 FE180/E90 MICA

- x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Circuit breakers with rating 3 A were used.

Measured time of tested specimens from S9 to S16

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S9	33-L1	no failure / interruption
	34-L2	no failure / interruption
	35-L3	no failure / interruption
	36-PEN	no failure / interruption
S10	37-L1	no failure / interruption
	38-L2	no failure / interruption
	39-L3	no failure / interruption
	40-PEN	no failure / interruption
S11	41-L1	no failure / interruption
	42-L2	no failure / interruption
	43-L3	no failure / interruption
	44-PEN	no failure / interruption
S12	45-L1	no failure / interruption
	46-L2	no failure / interruption
	47-L3	no failure / interruption
	48-PEN	no failure / interruption
S13	49-L1	no failure / interruption
	50-L2	no failure / interruption
	51-L3	no failure / interruption
	52-PEN	no failure / interruption
S14	53-L1	no failure / interruption
	54-L2	no failure / interruption
	55-L3	no failure / interruption
	56-PEN	no failure / interruption
S15	57-L1	no failure / interruption
	58-L2	no failure / interruption
	59-L3	no failure / interruption
	60-PEN	no failure / interruption
S16	61-L1	70:37
	62-L2	x
	63-L3	x
	64-PEN	x

Specimens 9,15: cables NHXCH 4x10 RE/10 FE180/E90 MICA
Specimens 10,16: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA
Specimens 11,13: cables NHXH 5x10 RE FE180/E90 MICA
Specimens 12,14: cables NHXH 4x1,5 RE FE180/E90 MICA

- x** conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Circuit breakers with rating 3 A were used.

Measured time of tested specimens from S17 to S24

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S17	65-L1	no failure / interruption
	66-L2	no failure / interruption
	67-L3	no failure / interruption
	68-PEN	no failure / interruption
S18	69-L1	no failure / interruption
	70-L2	no failure / interruption
	71-L3	no failure / interruption
	72-PEN	no failure / interruption
S19	73-L1	no failure / interruption
	74-L2	no failure / interruption
	75-L3	no failure / interruption
	76-PEN	no failure / interruption
S20	77-L1	no failure / interruption
	78-L2	no failure / interruption
	79-L3	no failure / interruption
	80-PEN	no failure / interruption
S21	81-L1	no failure / interruption
	82-L2	no failure / interruption
	83-L3	no failure / interruption
	84-PEN	no failure / interruption
S22	85-L1	no failure / interruption
	86-L2	no failure / interruption
	87-L3	no failure / interruption
	88-PEN	no failure / interruption
S23	89-L1	no failure / interruption
	90-L2	no failure / interruption
	91-L3	no failure / interruption
	92-PEN	no failure / interruption
S24	93-L1	no failure / interruption
	94-L2	no failure / interruption
	95-L3	no failure / interruption
	96-PEN	no failure / interruption

Specimens 17,18: cables NHXH 4x1,5 RE FE180/E90 MICA
Specimens 19,20: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA
Specimens 21,22: cables NHXCH 4x50 RM/25 FE180/E90 MICA
Specimens 23,24: cables NHXH 4x50 RM FE180/E90 MICA

- x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Circuit breakers with rating 3 A were used.

Measured time of tested specimens from S25 to S30

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S25	97-L1	no failure / interruption
	98-L2	no failure / interruption
	99-L3	no failure / interruption
	100-PEN	no failure / interruption
S26	101-L1	no failure / interruption
	102-L2	no failure / interruption
	103-L3	no failure / interruption
	104-PEN	no failure / interruption
S27	105-L1	64:19
	106-L2	64:19
	107-L3	64:19
	108-PEN	x
S28	109-L1	69:14
	110-L2	69:14
	111-L3	69:14
	112-PEN	x
S29	113-L1	61:53
	114-L2	61:53
	115-	61:53
	116-PEN	x
S30	117-L1	x
	118-L2	58:29
	119-L3	58:29
	120-PEN	x

Specimens 25,26: cables NHXH 4x50 RM FE180/E90 MICA
Specimens 27,28: cables (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC
Specimens 29,30: cables (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC

- x** conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Circuit breakers with rating 3 A were used.

Measured time of tested specimens from S52 to S60

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S52A	209-L	61:15
	210-PEN	x
S52B	211-L	no failure / interruption
	212-PEN	no failure / interruption
S53A	213-L	41:27
	214-PEN	x
S53B	215-L	61:15
	216-PEN	x
S54A	217-L	63:55
	218-PEN	x
S54B	219-L	58:27
	220-PEN	x
S55	221-L	no failure / interruption
	222-PEN	no failure / interruption
	223-L	no failure / interruption
	224-PEN	no failure / interruption
S56	225-L	no failure / interruption
	226-PEN	no failure / interruption
	227-L	no failure / interruption
	228-PEN	no failure / interruption
S57	229-L	no failure / interruption
	230-PEN	no failure / interruption
	231-L	no failure / interruption
	232-PEN	no failure / interruption
S58	233-L	no failure / interruption
	234-PEN	no failure / interruption
	235-L	no failure / interruption
	236-PEN	no failure / interruption
S59	237-L	no failure / interruption
	238-PEN	no failure / interruption
	239-L	no failure / interruption
	240-PEN	no failure / interruption
S60	241-L	no failure / interruption
	242-PEN	no failure / interruption
	243-L	no failure / interruption
	244-PEN	no failure / interruption

Specimens 52A,52B, 53A,53B,54A,54B:	bundle of six cables HTKSH(ekw) - 1x2x1,0 PH90
Specimens 55,56, 57,58,59,60:	bundle of six cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA

- x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Signal cables were tested by three-phase voltage supply 1 x 110V with LED diodes 3V / 0,03W. Circuit breakers with rating 3 A were used.

Measured time of tested specimens from S61 to S68


Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S61	245-L	no failure / interruption
	246-PEN	no failure / interruption
	247-L	no failure / interruption
	248-PEN	no failure / interruption
S62	249-L	no failure / interruption
	250-PEN	no failure / interruption
	251-L	no failure / interruption
	252-PEN	no failure / interruption
S63	253-L	no failure / interruption
	254-PEN	no failure / interruption
	255-L	no failure / interruption
	256-PEN	no failure / interruption
S64	257-L	no failure / interruption
	258-PEN	no failure / interruption
	259-L	no failure / interruption
	260-PEN	no failure / interruption
S65	261-L	no failure / interruption
	262-PEN	no failure / interruption
	263-L	no failure / interruption
	264-PEN	no failure / interruption
S66	265-L	75:53
	266-PEN	x
	267-L	75:53
	268-PEN	x
S67	269-L	51:18
	270-PEN	x
	271-L	x
	272-PEN	x
S68	273-L	x
	274-PEN	x
	275-L	87:53
	276-PEN	x

Specimens 61,62: cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA
Specimens 63,64: cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA
Specimens 65,66: cables JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC
Specimens 67,68: cables JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC

- x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Signal cables were tested by three-phase voltage supply 1 x 110V with LED diodes 3V / 0,03W.
Circuit breakers with rating 3 A were used.

Layout of cables in the test furnace




Specimens 1,2: cables NHXH 4x1,5 RE FE180/E90 MICA		Specimens placed in the basket cable tray (BAKS) Suspension track No.1
Specimens 3,4: cables NHXH 4x50 RM FE180/E90 MICA		
Specimens 5,6: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA		Specimens placed in the basket cable tray (BAKS) Suspension track No.2
Specimens 7,8: cables NHXCH 4x50 RM/25 FE180/E90 MICA		
Specimens 9,15: cables NHXCH 4x10 RE/10 FE180/E90 MICA		Specimens placed in the basket cable tray (BAKS) Suspension track No.3
Specimens 10,16: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA		
Specimens 11,13: cables NHXH 5x10 RE FE180/E90 MICA		
Specimens 12,14: cables NHXH 4x1,5 RE FE180/E90 MICA		
Specimens 17,18: cables NHXH 4x1,5 RE FE180/E90 MICA		Specimens placed in ceiling clips KSA (BAKS) in spacing of 600 mm
Specimens 19,20: cables NHXCH 4x1,5 RE/1,5 FE180/E90 MICA		
Specimens 21,22: cables NHXCH 4x50 RM/25 FE180/E90 MICA		
Specimens 23,24: cables NHXH 4x50 RM FE180/E90 MICA		
Specimens 25,26: cables NHXH 4x50 RM FE180/E90 MICA		Specimens placed in ceiling profile ledges with clips UKO (BAKS) in spacing of 300 mm
Specimens 27,28: cables (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC		
Specimens 29,30: cables (N)HXCH 4x1,5 RE/1,5 FE180/E90 CERAMIC		Specimens placed in ceiling clips OZMO (BAKS) in spacing of 300 mm
Specimens 52A,52B, 53A,53B,54A,54B:	bundle of six cables HTKSH(ekw) 1x2x1,0 PH90	Specimens placed in the basket cable tray (BAKS) Suspension track No.4
Specimens 55,56, 57,58,59,60:	bundle of six cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA	
Specimens 61,62: cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA		Specimens placed in the basket cable tray (BAKS) Suspension track No.1
Specimens 63,64: cables JE-H(St)H - 2x2x0,8 FE180/E90 MICA		Specimens placed in ceiling clips KSA (BAKS) in spacing of 600 mm
Specimens 65,66: cables JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC		Specimens placed in ceiling profile ledges with clips UKO (BAKS) in spacing of 300 mm
Specimens 67,68: cables JE-H(St)H - 2x2x0,8 FE180/E90 CERAMIC		Specimens placed in ceiling clips OZMO (BAKS) in spacing of 300 mm

Photos taken before the test




Photos taken after the termination of the test



Data 14.12.2007

BAKS -Bitner Badania FIRES Batizowce


 FIRES S.T.O. POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 15.12.2007 Podpis/Signature 
	Dokument №. Document No. <i>FIRES-FR-239-04-MWE</i>
	Załącznik №. Appendix No. <i>13</i>






Nr	Symbol kaba	Pozycja	Przekrój kabla	Konstrukcja mocowania, odległość, obciążenie	Uwagi
1	JE-H(St)H 180/ E90 Ceramic	1	2x2x 0.8	OZMO 0.3m / 1,1 kg/m	
2	(N)HXCH FE 180/ E90 Ceramik		4x 1,5/1,5	OZMO 0.3m / 1,1 kg/m	
3	JE-H(St)H 180/ E90 Ceramic		2x2x 0.8	OZMO 0.3m / 1,1 kg/m	
4	(N)HXCH FE 180/ E90 Ceramik		4x 1,5/1,5	OZMO 0.3m / 1,1 kg/m	
5	(N)HXCH FE 180/ E90 Ceramic	2	4x 1,5/1,5	UK1+ SDOC 0.3m	
6	(N)HXCH FE 180/ E90 Ceramic		4x 1,5/1,5	UK1+ SDOC 0.3m	
7	NHXXH FE 180 E90 Mika		4x 50	UK1+ SDOC 0.3m	
8	NHXXH FE 180 E90 Mika		4x 50	UK1+ SDOC 0.3m	
9	JE-H(St)H 180/ E90 Ceramic		2x2x 0.8	UK1+ SDOC 0.3m	
10	JE-H(St)H 180/ E90 Ceramic		2x2x 0.8	UK1+ SDOC 0.3m	
11	JE-H(St)H 180/ E90 Mika	3	2x2x0,8	KSA 0.6m	
12	JE-H(St)H 180/ E90 Mika		2x2x0,8	KSA 0.6m	
13	NHXXH FE 180/ E90 Mika		4x 50	KSA 0.6m	
14	NHXXH FE 180/ E90 Mika		4x 50	KSA 0.6m	
15	NHXXCH FE 180/ E90 Mika		4x 50/25	KSA 0.6m	
16	NHXXCH FE 180/ E90 Mika		4x 50/25	KSA 0.6m	
17	NHXXCH FE 180/ E90 Mika		4x 1,5/1,5	KSA 0.6m	
18	NHXXCH FE 180/ E90 Mika		4x 1,5/1,5	KSA 0.6m	
21	NHXXH FE 180/ E90 Mika		4x 1,5	KSA 0.6m	
22	NHXXH FE 180/ E90 Mika		4x 1,5	KSA 0.6m Puszka Spelsberg WKE 2	
23	NHXXCH FE 180/ E90 Mika	4	4x 50/25	Korytko siatkowe B-400 1.2 m/ 20kg/m	
24	NHXXCH FE 180/ E90 Mika		4x 50/25	Korytko siatkowe B-400 1.2 m/ 20kg/m	
27	NHXXCH FE 180/ E90 Mika		4x 1,5/1,5	Korytko siatkowe B-400 1.2 m/ 20kg/m	
28	NHXXCH FE 180/ E90 Mika		4x 1,5/1,5	Korytko siatkowe B-400 1.2 m/ 20kg/m	
29	JE-H(St)H 180/ E90 Mika	5	2x2x 0.8	Korytko siatkowe B-400 1.2 m/ 20kg/m	
30	JE-H(St)H 180/ E90 Mika		2x2x 0.8	Korytko siatkowe B-400 1.2 m/ 20kg/m	
31	NHXXH FE 180/ E90 Mika		4x 50	Korytko siatkowe B-400 1.2 m/ 20kg/m	
32	NHXXH FE 180/ E90 Mika		4x 50	Korytko siatkowe B-400 1.2 m/ 20kg/m	
33	NHXXH FE 180/ E90 Mika		4x 1,5	Korytko siatkowe B-400 1.2 m/ 20kg/m	
34	NHXXH FE 180/ E90 Mika		4x 1,5	Korytko siatkowe B-400 1.2 m/ 20kg/m	
35	Wiązka 6 kabli JE-H(St)H 180/ E90 Mika		2x2x0,8	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
36	Wiązka 6 kabli HTKSH 2x1 PH 90		2x1	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
37	NHXXCH FE 180/ E90 Mika	6	4x 1,5/1,5	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
38	NHXXCH FE 180/ E90 Mika		4x10/10	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
39	NHXXH FE 180/ E90 Mika		4x 1,5	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
40	NHXXH FE 180/ E90 Mika		5x10	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	

Nr	Symbol kaba	Pozycja	Przekrój kabla	Konstrukcja mocowania, odległość, obciążenie	Uwagi
41	NHXXH FE 180/ E90 Mika		4x 1,5	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
42	NHXXH FE 180/ E90 Mika		5x10	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
43	NHCXH FE 180/ E90 Mika		4x 1,5/1,5	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	
44	NHXCH FE 180/ E90 Mika		4x10/10	Korytko siatkowe B-60 1.2 m/ 1,5kg/m	

Lp	Symbol kaba	Średnica kabla	Ciężar kabla	
1	NHXCH FE 180/ E90 4x 50/25 Mika	38mm	3.3 kg/m	
2	NHXXH FE 180/ E90 4x 50 Mika	36 mm	3.05 kg/m	
3	(N)HXCH FE 180/ E90 4x 1,5/1,5 Ceramik	16mm	0.36 kg/m	
4	NHXCH FE 180/ E90 4x 1,5/1,5 Mika	17,6 mm	0.42 kg/km	
5	NHXXH FE 180/ E90 4x 1,5 Mika	15mm	0.34 kg/m	
6	NHXCH FE 180/ E90 4x 10/10 Mika	25,2 mm	1,1 kg/km	
7	NHXXH FE 180/ E90 5x 10 Mika			
8	JE-H(St)H 2x2x 0.8 FE 180/ E90 Ceramik	12,5 mm	0,16 kg/km	
9	JE-H(St)H 2x2x 0.8 FE 180/ E90 Mika	12 mm	0,18 kg/m	
10	HTKSA 2 x1 PH 90	mm	kg/m	

Mocowanie do betonu : pozycja 1,2,5,6, śruby SRO M6x 30
pozycja 4 zacisk ZK8 śruby PSRO M10x 80
pozycja 5 (korytka) śruby PSRO M10x 80
pozycja 3 śruby SRO M6x 30 + tuleje TRSO M6x 30




	Datum/date 13. 4. 2008
	Podpis/Signature <i>[Signature]</i>
Dokument č. Document No. FIRES-FR-234-08-AWC	
Príloha č./Appendix No. 44	



Pos.1		Pos.4
A	Typ	Typ
60	KDS060H60/3	CWP40H40/02
100	KDS100H60/3	
150	KDS150H60/3	
200	KDS200H60/3	
300	KDS300H60/3	
	KDS400H60/3	CWP40H40/03
		CWP40H40/04
		CWP40H40/05


1	liczby surowe	10000	2	10000
2	surowe	10000	10	10000
3	surowe	10000	10	10000
4	surowe	10000	10	10000
5	surowe	10000	10	10000
6	surowe	10000	10	10000
7	surowe	10000	10	10000
8	surowe	10000	10	10000
9	surowe	10000	10	10000
10	surowe	10000	10	10000
11	surowe	10000	10	10000
12	surowe	10000	10	10000
13	surowe	10000	10	10000
14	surowe	10000	10	10000
15	surowe	10000	10	10000
16	surowe	10000	10	10000
17	surowe	10000	10	10000
18	surowe	10000	10	10000
19	surowe	10000	10	10000
20	surowe	10000	10	10000
21	surowe	10000	10	10000
22	surowe	10000	10	10000
23	surowe	10000	10	10000
24	surowe	10000	10	10000
25	surowe	10000	10	10000
26	surowe	10000	10	10000
27	surowe	10000	10	10000
28	surowe	10000	10	10000
29	surowe	10000	10	10000
30	surowe	10000	10	10000
31	surowe	10000	10	10000
32	surowe	10000	10	10000
33	surowe	10000	10	10000
34	surowe	10000	10	10000
35	surowe	10000	10	10000
36	surowe	10000	10	10000
37	surowe	10000	10	10000
38	surowe	10000	10	10000
39	surowe	10000	10	10000
40	surowe	10000	10	10000
41	surowe	10000	10	10000
42	surowe	10000	10	10000
43	surowe	10000	10	10000
44	surowe	10000	10	10000
45	surowe	10000	10	10000
46	surowe	10000	10	10000
47	surowe	10000	10	10000
48	surowe	10000	10	10000
49	surowe	10000	10	10000
50	surowe	10000	10	10000
51	surowe	10000	10	10000
52	surowe	10000	10	10000
53	surowe	10000	10	10000
54	surowe	10000	10	10000
55	surowe	10000	10	10000
56	surowe	10000	10	10000
57	surowe	10000	10	10000
58	surowe	10000	10	10000
59	surowe	10000	10	10000
60	surowe	10000	10	10000
61	surowe	10000	10	10000
62	surowe	10000	10	10000
63	surowe	10000	10	10000
64	surowe	10000	10	10000
65	surowe	10000	10	10000
66	surowe	10000	10	10000
67	surowe	10000	10	10000
68	surowe	10000	10	10000
69	surowe	10000	10	10000
70	surowe	10000	10	10000
71	surowe	10000	10	10000
72	surowe	10000	10	10000
73	surowe	10000	10	10000
74	surowe	10000	10	10000
75	surowe	10000	10	10000
76	surowe	10000	10	10000</

This drawing and its contents is the property of the S&B company and may not be reproduced or otherwise disclosed to any third party without our consent. Conventions will be proscribed.





FIRES S.T.O. POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Data 13.11.2008
	Podpis/Signature <i>[Signature]</i>
	Dokument & Document No. <i>FIRES-FD-234-04-ANUL</i>
Priloha &/Appendix No. <i>12</i>	


B	Typ
215	CWDP40H40/02
315	CWDP40H40/03
415	CWDP40H40/04
515	CWDP40H40/05




Odczytka wyników nieolerowanych	Materiał Gotunek Nr normy półfabrykat (nr normy)	PN-EN 10327:2005	Masa (kg) 1,2	Liczba 1:2	Format A4
Projektował	J. GRACHOWSKI	Data 20.10.05 20.10.05 20.10.05 20.10.05	CWDP40H40/...		
Rysował	J. Grachowski				
Sprawdził	T. WŁODARCZYK				
Zatwierdził	J. KLICZEK				
Profesjonalne Systemy Tras Kablowych			Nr zleń [Grid]		




 FIRES S.R.O. POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 13.12.2008 Podpis/Signature <i>[Signature]</i>
	Dokument č. Document No. <i>FIRES-FR-234-01-ANKE</i>
Příloha č. / Appendix No. <i>18</i>	

	Dachylka wynórów nietolerowanych	Materiał Gotunek Nr normy półfabrykat (nr normy)	PN EN 10327:2005	Masa (kg) Poziostka 1:1	Format A4 Arkusz 1 Arkusz 1
Projektował T.Grudniewski	Nazwa J.Jasinski J.Kliczek	Podpis _____ _____ _____	Data 2004.12.29 2004.12.29 2004.12.29 2004.12.29	Nazwa rysunku <i>USDV</i>	
Rysował J.Jasinski				Nr projektu maszynowego ---	Nr złoty _____ _____ _____
Sprawdzał J.Kliczek					
Zatwierdził J.Kliczek				Profesjonalne Systemy Tras Kablowych	




WKS060



SPS060

KDS060H60





	Datum/Date 15.12.2007
	Podpis/Signature
Dokument No. FIRPS - 12-239-01.001	Dokument No. 12-239-01.001
Příloha č. 1/1	Příloha č. 1/1


Projekt Projektant Projektant	Dle Dle	Datum 19.12.2007	Název ZAWIESIE DO KDS060H60	Měřítko 1:1	Formát A4
Dle Dle	Dle Dle	Dle Dle	Dle Dle	Dle Dle	Dle Dle
Dle Dle	Dle Dle	Dle Dle	Dle Dle	Dle Dle	Dle Dle

Profesionální Systémy
Tras Kablových






 FIRES s.r.o. POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 15. 12. 2008
	Podpis/Signature 
Dokument 6. <i>FIRES-FR-RS4-OK-PAGE</i> Document No.	
Priloha 8 /Appendix No. <i>21</i>	



 Daktylik nietolerowanych			Materiał Gatunek Nr normy półfabrykat (nr normy)	Masa [kg] Podział	Skala 1:1	Format A4 Arkusz 1 Kładzie 1
Projektował	Nazwisko _____ _____ _____ _____	Pismo _____ _____ _____ _____	Data _____ _____ _____ _____	Nazwa rysunku WKS060		
Rysował						
Sprawdził						
Zatwierdził						
Nr programu maszynowego ---				Nr zleń _____ _____ _____ _____		
Nr rysunku _____ _____ _____ _____				_____ _____ _____ _____		








Profesjonalne Systemy
Tras Kablowych





 FIRES S.I.O. POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 13.12.2007  Podpis/Signature
	Dokument & Document No. <i>FIRES-FR-250-06-BWE</i>
Załącznik &/Appendix No. <i>22</i>	


	Odczytywanie wymiarów nie tolerowanych	Materiał Gotunek Nr normy półfabrykat (nr normy)	Masa (kg) Podziałka 1:1	Format A4 Kłuski 1 Kłuski 1
Projektował Rysował Sprawdził Zatwierdził	Nazwa _____ _____ _____ _____	Podpis _____ _____ _____ _____	Data 10.12.2007 _____ _____ _____	Nazwa rysunku SKD60 Nr programu rysunkowego --- Nr rysunku _____
 Profesjonalne Systemy Tras Kablowych				Nr zlecenia _____ _____ _____



 FIRES s.r.o. POŻIARNA OTOCZNOŚĆ FIRE RESISTANCE	Datum/Date 13. 11. 2006 Podpis/Signature 
	Dokument 5. Document No. <i>FIRES-FR-239-DE-ANNE</i>
Příloha 6/Appendix No. <i>23</i>	


symbol	A	B	C	D
KSA 6	5	9	11	12
KSA 8	7	15	11	12
KSA 10	9	17	11	12
KSA 12	11	19	11	12
KSA 14	13	22	11	12
KSA 16	15	24	11	12
KSA 18	17	26	11	12
KSA 20	19	27	11	12
KSA 22	21	29	11	14
KSA 24	23	31	11	14
KSA 25	24	32	11	14
KSA 26	25	33	11	14
KSA 28	27	35	11	14
KSA 32	31	39	11	14
KSA 33	32	40	12	16
KSA 35	34	42	12	16
KSA 36	35	45	12	16
KSA 40	39	47	12	16
KSA 42	41	49	12	16
KSA 48	46	56	14	16
KSA 50	48	58	14	16
KSA 55	53	62	14	16

	Odczytka wyniarów nie tolerowanych	Nr. rysunku Nr. normy półfabrykat (nr. normy)	Masa [kg] Podziałka 1/1	Format A4 Arkusze 1 Arkuszy 1
Projektant J. GROCHOWSKI	Narysował J. GROCHOWSKI	Data 20.10.04	Nazwa rysunku KSA	
Sprawdził T. WŁODARCZYK	Podpis 	Data 20.10.04	Nr programu maszynowego ---	
Zatwierdził J. KŁCZEK	Data 20.10.04	Nr rysunku ---		Nr zmiany ---
Profesjonalne Systemy Tras Kablowych				



 FIRES S.p.A. POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Czas 15.12.2001  Podpis/Signature
	Dokument o. Document No. <i>FIRES-PR-234-08. ANE</i> Załącznik o./Appendix No. <i>29</i>

	Odchyłka wymiarów nieolerowanych		Materiał	Gatunek		Masa (kg)	Podziałka	Zakres	A4	
				Nr normy						
			golfabryka (nr normy)		PN-EN 10327:2005		1:1		Arkusze	
									Arkusze	
Projektował			Materiał	Przebieg	Data		Nazwa rysunku			
Rysował							28-Jun-06			
Sprawdził										
Zatwierdził										
			Nr programu maszynowego				Nr zmiany			
			Nr rysunku							
			Profesjonalne Systemy Tras Kablowych							











FIRES S.R.O.
POŻIARNA ODOLNOŚĆ
FIKE RESISTANCE

13.12.2024
Podpis/Signature

Dokument & / Document No. **FIRES-PR-235-01-ANU**

Priloha & / Appendix No. **25**



 	Odchyłka wymiarów instalacyjnych		Materiał	Gatunek		Masa [kg]	Przełaz	Format
				Nr normy	PN-EN 10142 + A1 : 1997			A4
				półfabrykat (nr normy)			1:1	Arkusz
Projektował	Nazwisko J. Gruchowski	Podpis	Data	Nazwa rysunku				
Rysował				OZMO				
Sprawdził								
Zatwierdził								
				Nr programu WYTYCZNIKI		Nr zniszc		