

## **TEST REPORT FIRES-FR-235-07-AUNE**

### **Cable bearing system BAKS**



*This is an electronic version of a test report which was made as a copy of test report officially issued in a paper form. The electronic version of a test report shall be used only for informative purposes. Any information listed in this test report is the property of the sponsor and shall not be used or published without written permission. Contents of this file may only be modified by the editor i.e. Testing laboratory FIRES s.r.o. Batizovce. Sponsor is allowed to publish this test report in parts only with written permission of the editor.*

**FIRES, s.r.o.**

Notifikovaná osoba č./ Notified Body No.: 1396

Autorizovaná osoba reg. č./Approved Body No.: SK01

Osloboditeľov 282, 059 35 Batizovce, Slovakia

Tel.+421 52 775 2298, Fax+421 52 7881412, e-mail: info@fires.sk, [www.fires.sk](http://www.fires.sk)

Reg. No. 041/S-159

Testing laboratory No. 041/S-159 accredited by  
Slovak national accreditation service

# TEST REPORT

Test report number: **FIRES-FR-235-07-AUNE**

Tested property: Function in fire

Test method: DIN 4102 – 12:1998-11

Date of issue: **14. 01. 2008**

Name of the product: Cable bearing system BAKS

Manufacturer: **BAKS Kazimierz Sielski**, Jagodne 5,  
05-480 Karczew, Poland - producer of construction**TECHNOKABEL S.A.**, Nasielska 55,  
04-343 Warszawa, Poland – producer of cablesSponsor: **BAKS Kazimierz Sielski**, Jagodne 5, 05-480 Karczew, Poland

Task No.: PR-07-0423

Specimen received: 17. 12. 2007

Date of the fire test: 20. 12. 2007

Technician responsible for the technical side of this report: Miroslav Hudák

Number of pages: 6

Number of appendices: 27

Test reports: 3

Copy No.: 2

Distribution list:

Copy No.1: **FIRES, s.r.o.**, Osloboditeľov 282, SK-059 35 Batizovce, Slovakia  
(electronic version)Copy No.2: **BAKS Kazimierz Sielski**, Jagodne 5, 05-480 Karczew, Poland  
(electronic version)Copy No.3: **BAKS Kazimierz Sielski**, Jagodne 5, 05-480 Karczew, Poland

## 1. INTRODUCTION

This test report contains the results of the test carried out at the testing laboratory of FIRES s.r.o. in Batizovce. The purpose of the test was product classification. The test specimen was power and communication non-halogen cables with circuit integrity maintenance. Persons witnessing the test:

Representatives of the sponsor: Mr. Jacek Kliczek (BAKS)  
Mr. Mariusz Kwiatkowski (TECHNOKABEL)

Test directed by: Mr. Štefan Rástocký  
Test carried out by: Mr. Miroslav Hudák  
Operator: Mr. Ján Hurajt

## 2. MEASURING EQUIPMENT

Identification number	Measuring equipment	Note
F 90 002	Horizontal test furnace for fire testing	-
F 69 005	PLC system for data acquisition and control TECOMAT NS 950	-
F 40 008	Software Control Web 2000	
F 40 009	Control and communication software to PLC TECOMAT NS 950	
F 40 010	Visual and calculating software to PLC TECOMAT NS 950	-
F 40 011	Driver Tecomat – CW 2000 (software)	-
F 71 008, F 71 009	Transducer of differential pressure (from -50 to +150) Pa	pressure inside the test furnace
F 06 501, F 06 502, F 06 503, F 06 504 F 06 505, F 06 506, F 06 507, F 06 508	Plate thermometers	temperature inside the test furnace, according to EN 1363-1 a DIN 4102-2
F 06 701	Sheathed thermocouple type K $\phi$ 3 mm	ambient temperature
F 69 009	PLC system for data acquisition and climate control TECOMAT TC 604	climatic conditions
F 60 001 – F 60 009	Temperature and relative air humidity sensors	climatic conditions
F 54 057	Racking meter	-
F 57 007	Digital stop-watch	-
F 96 015	Test signal panel	-

## 3. PREPARATION OF THE SPECIMEN

Testing laboratory didn't take off individual components of the specimen. Components take-off and its delivering to the testing laboratory were carried out by the test sponsor. Assembling of the supporting system into the test furnace was carried out by workers of the test sponsor. Mounting of cables and weights into the supporting system was carried out by workers businesses BAKS and TECHNOKABEL.

## 4. PREPARATION OF THE TEST

### 4.1 DESCRIPTION OF THE SPECIMEN STRUCTURE

Test specimen comprised from cable bearing systems BAKS with accessories – cable trays, cable ladders, basket cable trays, ceiling ledges SDOC with clips UKO1, clips UEF, UDF and power and communication non-halogen cables business TECHNOKABEL.

Cables:

(N)HXH 4x1,5 RE FE180 PH30/E30-E60	( 2 x )
(N)HXH 4x50 RM FE180 PH30/E30-E60	( 6 x )
(N)HXCH 4x1,5/1,5 RE FE180 PH30/E30-E60	( 2 x )
(N)HXCH 4x50/25 RM FE180 PH30/E30-E60	( 6 x )
(N)HXH 4x1,5 RE FE180 PH90/E90	( 10 x )
(N)HXH 4x50 RM FE180 PH90/E90	( 2 x )
(N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	( 6 x )
(N)HXCH 4x50/25 RM FE180 PH90/E90	( 2 x )
HTKSH 1x2x0,8 FE180 PH90/E30-E90	( 12 x )
HTKShkw 1x2x0,8 FE180 PH90/E30-E90	( 6 x )

Ceiling installation: was made by ceiling ledges (type SDOC 600) and cable clips (type UEF, UDF). Ceiling ledges were fixed to ceiling by three dowels (type PRSO M8x75) in spacing of 600 mm. Cables were fixed to ledges by clips (type UKO1) in spacing of 600 mm. Cable clips (type UEF, UDF) depending on the diameter of cable were fixed to ceiling by dowels (type SRO M6x30) in spacing of 600 mm.

Suspension track No. 1: was made of three consoles combined of two horizontal supports (type CWOP40H40/05) and two threaded bar M10x600 with washers and nuts M10 and two hangers (type USOV) which were fixed to ceiling by dowels (type PRSO M8x75) in spacing of 1200 mm. Basket cable trays (type KDSO400H60) were fixed to horizontal supports. Load-bearing system was loaded with 20 kg/m.

Suspension track No. 2: was made of three consoles combined of horizontal support (type CWOP40H40/05) and two threaded bar M8x300 with washers and nuts M8 and two hangers (type ZK8) which were fixed to steel profiles I 80. These profiles were fixed to ceiling by four dowels (type PRSO M8x75) in spacing of 1200 mm. Basket cable trays (type KDSO400H60) were fixed to horizontal supports. Load-bearing system was loaded with 10 kg/m.

Suspension track No. 3: was made of four consoles (type WKS060) which were fixed to ceiling by dowels (type SRO M6x30) in spacing of 1200 mm. Basket cable trays (type KDSO60H60) were fixed to consoles. Load-bearing system was loaded with 1,5 kg/m.

Suspension track No. 4: was made by three hangers (type WPCO 800) which were fixed to ceiling by four dowels (type PSRO M10x80) in spacing of 1500 mm. Four booms (type WMCO 400) were fixed by screws (type SM M10 x 70) at each hanger. Holders (type UPWO) were fixed at the end of booms. Booms were fixed through these holders by threaded bar M10 with washers and nuts M10 to ceiling holder (type USOV) which was fixed to ceiling by dowel (type PSRO M10x80).

Trays (type KCOP 400H60/3) were fixed at upper booms and jointed together by two junctions (type LPOPH60N) and by sheet (type BLO400N) with screws M6 (type SGN M6x12). Trays were fixed to booms by screws M6 (type SGN M6x12). Trays were loaded with 10 kg/m.

Ladders (type DGOP 400H60N) were fixed at bottom booms and jointed together by junction (type LDOCH60N) with screws M8 (type SGN M8x14). Ladders were fixed to booms by clips (type ZMO) with screws M8 (type SGN M8x14). Ladders were loaded with 20 kg/m.

Types of individual components are from catalogue BAKS 8/2006.

Cable penetration through the wall of test furnace was sealed by mineral wool Rockwool.

Loading with steel chain were used as the equivalent load.

More detailed information about specimen construction is shown in the drawings which form the appendix of this test report. Drawings were delivered by the sponsor of the test.

All the information about technical specifications of used materials and semi-products, information about their type sign and their producers were delivered by sponsor. This information was not subject of the specimen inspection. Parameters which were checked are quoted in paragraph 4.3 SPECIMEN INSPECTION.

#### 4.2 DESCRIPTION OF THE SPECIMEN FIXATION

The test specimen was fixed on the ceiling of the test furnace which was created from concrete panels made of common shocked concrete of class B 20, 150 mm thick.

The type of specimen fixation into the test furnace is visible in drawing documentation and it was selected by the sponsor.

#### 4.3 SPECIMEN INSPECTION

Before and after the fire testing, conformity of the test specimen with drawing was checked. The specimen corresponded to the drawing which create appendix of this report.

Specimen inspection consisted of visual review of the test specimen as well as size verification (number and cross sections of conductors, thickness, measurements of cables and trays).

#### 4.4 CLIMATIC CONDITIONING

Test specimens were stored in the climatic hall and conditioned according to EN 1363-1 under the following climatic conditions:

Relative air humidity [%]		Ambient air temperature [°C]	
mean	standard deviation	mean	standard deviation
46,7	2,1	22,6	0,5

The equilibrium state of test specimen humidity was not determined. The test specimen did not comprise hygroscopic material.

### 5. CARRYING OUT THE TEST

#### 5.1 TEST CONDITIONS

Conditions in the test furnace (temperature, pressure, content O<sub>2</sub> content) as well as conditions in the testing room (ambient temperature) corresponded to EN 1363-1 and DIN 4102-2 during the whole test. Detailed information is shown in appendices of this report or in quality records of the testing laboratory.

Values characterising environment in the testing room directly before the test:

Date of fire test	Relative air humidity [%]	Ambient air temperature [°C]
20. 12. 2007	43,6	10,7

## 5.2 TEST RESULTS

The measured values are shown in tables that form an integral part of this test report.

## 5.3 EVALUATION OF THE TEST

<b>Specimens</b>	<b>Time to first failure/interruption of conductor</b>
Specimen 1: cable (N)HXCH 4x50/25 RM FE180 PH90/E90	<b>81 minutes</b>
Specimen 2: cable (N)HXCH 4x50/25 RM FE180 PH90/E90	<b>88 minutes</b>
Specimen 3: cable (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	<b>62 minutes</b>
Specimen 4: cable (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	<b>51 minutes</b>
Specimen 5: cable (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimen 6: cable (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	<b>79 minutes</b>
Specimen 7: cable (N)HXH 4x1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimen 8: cable (N)HXH 4x50 RM FE180 PH30/E30-E60	<b>7 minutes</b>
Specimen 9: cable (N)HXH 4x50 RM FE180 PH30/E30-E60	<b>77 minutes</b>
Specimens 10,11: cables (N)HXH 4x50 RM FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimens 12,13: cables (N)HXH 4x1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimen 14: cable (N)HXCH 4x1,5/1,5 RE FE180 PH30/E30-E60	<b>78 minutes</b>
Specimen 15: cable (N)HXCH 4x1,5/1,5 RE FE180 PH30/E30-E60	<b>67 minutes</b>
Specimen 16: cable (N)HXH 4x1,5 RE FE180 PH30/E30-E60	<b>81 minutes</b>
Specimen 17: cable (N)HXH 4x1,5 RE FE180 PH30/E30-E60	<b>73 minutes</b>
Specimens 18,19: cables (N)HXH 4x1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimen 20: cable (N)HXH 4x1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimens 21, 22: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimens 23, 24: cables (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	<b>90 minutes no failure/interruption</b>
Specimens 25, 26: cables (N)HXH 4x1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimens 27, 28: cables (N)HXH 4x50 RM FE180 PH30/E30-E60	<b>90 minutes no failure/interruption</b>
Specimens 29, 30: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimen 31: cable (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	<b>64 minutes</b>
Specimen 32: cable (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	<b>55 minutes</b>
Specimens 33, 34: cables (N)HXH 4x1,5 RE FE180 PH90/E90	<b>90 minutes no failure/interruption</b>
Specimen 35: cable (N)HXH 4x50 RM FE180 PH30/E30-E60	<b>17 minutes</b>
Specimen 36: cable (N)HXH 4x50 RM FE180 PH30/E30-E60	<b>62 minutes</b>
Specimens 53A,B: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>90 minutes no failure/interruption</b>
Specimens 54A,B: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>90 minutes no failure/interruption</b>
Specimen 55A: HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	<b>38 minutes</b>
Specimen 55B: HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	<b>41 minutes</b>
Specimen 59A: HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	<b>65 minutes</b>
Specimen 59B: HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	<b>75 minutes</b>
Specimen 63A: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>90 minutes no failure/interruption</b>
Specimen 63B: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>48 minutes</b>
Specimen 64B: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>90 minutes no failure/interruption</b>
Specimens 70A,B: HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	<b>90 minutes no failure/interruption</b>
Specimen 71A: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>81 minutes</b>
Specimen 71B: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>90 minutes no failure/interruption</b>
Specimen 74A,B: HTKSH 1x2x0,8 FE180 PH90/E30-E90	<b>90 minutes no failure/interruption</b>

The fire test was discontinued in 93<sup>rd</sup> minute at the request of sponsor.


Specimens S1 – S36 were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.  
Specimens S52 – S75 were tested by one-phase voltage supply 1 x 110V with LED diodes 3V /0,03W.

## 6. CLOSING

- This report details the method of construction, the test conditions and results obtained when the specific element of construction described herein was following the procedure outlined in EN 1363-1 and DIN 4102 – 12:1998-11. Any significant deviation with respect to size, constructional details, loads, stresses, edges or end conditions other than those allowed under the field of direct application in the relevant test method is not covered by this report.
- Because of the nature of the fire resistance testing and consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.
- The test results refer only to the tested subjects. This test report is not an approval of the tested product by the test laboratory or the accreditation body overseeing the laboratory's activities. The test was carried out on testing equipment that is the property of FIRES Ltd. Without the written permission of the test laboratory this test report may be copied and/or distributed only as the whole. Any modifications of the test report can be made only by the fire resistance test laboratory FIRES Ltd. Batizovce.


**Report checked by:** Ing. Štefan Rástocký

**Translated by:** Ing. Marek Rusnák



**Issued by:**

**Responsible for the technical side of this report:**



Ing. Štefan Rástocký  
leader of the testing laboratory




Miroslav Hudák  
technician of the testing laboratory

## 7. NORMATIVE REFERENCES

DIN 4102 – 2:1977-09	Fire behaviour of building materials and elements - requirements and testing
DIN 4102 – 12:1998-11	Fire resistance of electric cable systems required to maintain circuit integrity
STN EN 1363-1:2001	Fire resistance tests – Part 1: General requirements

## 8. LIST OF APPENDICES

Appendix 1	Measured values inside the test furnace
Appendix 2	Measured values inside the test furnace / graph
Appendix 3	Measured times of tested specimens from S1 to S8
Appendix 4	Measured times of tested specimens from S9 to S16
Appendix 5	Measured times of tested specimens from S17 to S24
Appendix 6	Measured times of tested specimens from S25 to S32
Appendix 7	Measured times of tested specimens from S33 to S36
Appendix 8	Measured times of tested specimens from S53 to S74
Appendix 9	Layout of cables in the test furnace
Appendix 10-11	Photos taken before and after the fire test
Appendix 12- 27	Drawings

### Measured values inside the test furnace

Time t [min]	Temperature [°C]											Deviation d <sub>e</sub> [%]	Pressure p [Pa]
	Td1	Td2	Td3	Td4	Td5	Td6	Td7	Td8	Tave	Tn	To		
0	40,2	51,2	47,1	31,8	39,8	31,8	32,7	37,6	39,0	0,0	12,7	0,0	0,0
5	514,7	548,1	553,4	508,1	586,9	678,2	706,9	637,2	591,7	576,2	12,2	-13,5	12,4
10	627,7	646,2	621,0	614,2	697,1	703,8	732,8	766,7	676,2	678,3	12,2	-4,9	12,7
15	719,8	720,1	676,8	668,5	816,3	789,1	808,4	816,7	752,0	738,5	12,5	-3,1	13,1
20	756,0	754,8	773,6	718,4	810,0	830,4	854,2	803,7	787,6	781,3	12,2	-1,6	12,8
25	789,5	784,8	804,9	744,8	841,1	855,2	869,7	820,3	813,8	814,6	12,0	-1,1	13,9
30	821,7	836,4	826,3	754,8	870,1	889,0	881,8	823,0	837,9	841,8	12,1	-1,4	17,2
35	848,3	872,1	869,2	801,1	880,9	911,3	899,5	846,6	866,1	864,8	13,0	-1,1	17,8
40	860,8	876,7	863,9	810,8	902,4	921,4	901,4	845,6	872,9	884,7	13,7	-1,0	17,6
45	884,8	892,3	865,8	825,2	916,9	905,4	915,6	905,4	888,9	902,3	13,5	-1,1	16,6
50	908,2	908,7	882,8	850,9	939,3	923,7	935,4	918,8	908,5	918,1	13,4	-1,1	17,5
55	927,8	921,5	901,0	879,2	960,8	938,2	952,4	943,4	928,0	932,3	13,4	-1,1	17,4
60	938,1	935,1	917,4	899,0	973,3	953,7	971,2	958,2	943,3	945,3	13,6	-1,0	17,5
65	951,8	950,3	934,2	916,0	988,2	971,1	988,4	974,7	959,3	957,3	13,6	-0,9	17,5
70	963,8	963,6	947,3	932,0	997,7	984,9	1000,0	988,8	972,3	968,4	13,6	-0,8	17,6
75	976,9	976,4	964,2	949,0	1006,0	996,7	1016,0	1004,0	986,3	978,7	13,4	-0,7	17,0
80	983,3	985,7	973,3	956,1	1012,0	1003,0	1024,0	1014,0	994,2	988,4	12,6	-0,6	16,8
85	992,9	997,0	984,0	962,9	1019,0	1012,0	1032,0	1023,0	1003,0	997,4	13,3	-0,5	16,4
90	1003,0	1006,0	992,5	974,5	1029,0	1021,0	1039,0	1033,0	1012,7	1005,9	13,7	-0,4	16,3
91	1005,0	1009,0	994,6	975,2	1030,0	1023,0	1042,0	1032,0	1013,9	1007,6	13,6	-0,4	16,5
92	1004,0	1010,0	996,7	977,3	1032,0	1023,0	1043,0	1034,0	1015,4	1009,2	13,7	-0,4	16,2

**Tave** Average temperature in the test furnace calculated from plate thermometers


**Tn** Standard temperature in the test furnace laid down to test guideline

**To** Ambient temperature

**d<sub>e</sub>** Deviation of the average temperature from the standard temperature calculated according to test guideline


**p** Pressure inside the test furnace measured under the ceiling of the test furnace

**Layout of measuring points in the test furnace:**





Measured values inside the test furnace / graph



**Measured time of tested specimens from S1 to S8**

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S1	1-L1	81:57
	2-L2	x
	3-L3	x
	4-PEN	x
S2	5-L1	x
	6-L2	88:29
	7-L3	x
	8-PEN	x
S3	9-L1	x
	10-L2	x
	11-L3	62:33
	12-PEN	x
S4	13-L1	51:18
	14-L2	x
	15-L3	x
	16-PEN	x
S5	17-L1	no failure / interruption
	18-L2	no failure / interruption
	19-L3	no failure / interruption
	20-PEN	no failure / interruption
S6	21-L1	x
	22-L2	79:59
	23-L3	x
	24-PEN	x
S7	25-L1	no failure / interruption
	26-L2	no failure / interruption
	27-L3	no failure / interruption
	28-PEN	no failure / interruption
S8	29-L1	7:25
	30-L2	x
	31-L3	x
	32-PEN	x

Specimens 1,2: cables (N)HXCH 4x50/25 RM FE180 PH90/E90
Specimens 3,4: cables (N)HXCH 4x50/25 RM FE180 PH30/E30-E60
Specimens 5,6: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90
Specimen 7: cable (N)HXH 4x1,5 RE FE180 PH90/E90
Specimen 8: cable (N)HXH 4x50 RM FE180 PH30/E30-E60

- x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.  
Circuit breakers with rating 3 A were used.

### Measured time of tested specimens from S9 to S16

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S9	33-L1	x
	34-L2	x
	35-L3	77:48
	36-PEN	x
S10	37-L1	no failure / interruption
	38-L2	no failure / interruption
	39-L3	no failure / interruption
	40-PEN	no failure / interruption
S11	41-L1	no failure / interruption
	42-L2	no failure / interruption
	43-L3	no failure / interruption
	44-PEN	no failure / interruption
S12	45-L1	no failure / interruption
	46-L2	no failure / interruption
	47-L3	no failure / interruption
	48-PEN	no failure / interruption
S13	49-L1	no failure / interruption
	50-L2	no failure / interruption
	51-L3	no failure / interruption
	52-PEN	no failure / interruption
S14	53-L1	x
	54-L2	78:27
	55-L3	x
	56-PEN	x
S15	57-L1	67:53
	58-L2	x
	59-L3	x
	60-PEN	x
S16	61-L1	81:19
	62-L2	x
	63-L3	x
	64-PEN	x

Specimen 9: cable (N)HXH 4x50 RM FE180 PH30/E30-E60
Specimens 10,11: cables (N)HXH 4x50 RM FE180 PH90/E90
Specimens 12,13: cables (N)HXH 4x1,5 RE FE180 PH90/E90
Specimens 14,15: cables (N)HXCH 4x1,5/1,5 RE FE180 PH30/E30-E60
Specimen 16: cables (N)HXH 4x1,5 RE FE180 PH30/E30-E60

- x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Circuit breakers with rating 3 A were used.

**Measured time of tested specimens from S17 to S24**

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S17	65-L1	x
	66-L2	73:14
	67-L3	x
	68-PEN	x
S18	69-L1	no failure / interruption
	70-L2	no failure / interruption
	71-L3	no failure / interruption
	72-PEN	no failure / interruption
S19	73-L1	no failure / interruption
	74-L2	no failure / interruption
	75-L3	no failure / interruption
	76-PEN	no failure / interruption
S20	77-L1	no failure / interruption
	78-L2	no failure / interruption
	79-L3	no failure / interruption
	80-PEN	no failure / interruption
S21	81-L1	no failure / interruption
	82-L2	no failure / interruption
	83-L3	no failure / interruption
	84-PEN	no failure / interruption
S22	85-L1	no failure / interruption
	86-L2	no failure / interruption
	87-L3	no failure / interruption
	88-PEN	no failure / interruption
S23	89-L1	no failure / interruption
	90-L2	no failure / interruption
	91-L3	no failure / interruption
	92-PEN	no failure / interruption
S24	93-L1	no failure / interruption
	94-L2	no failure / interruption
	95-L3	no failure / interruption
	96-PEN	no failure / interruption

Specimen 17: cable (N)HXH 4x1,5 RE FE180 PH30/E30-E60
Specimens 18,19: cables (N)HXH 4x1,5 RE FE180 PH90/E90
Specimen 20: cable (N)HXH 4x1,5 RE FE180 PH90/E90
Specimens 21,22: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90
Specimens 23,24: cables (N)HXCH 4x50/25 RM FE180 PH30/E30-E60

- x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.  
Circuit breakers with rating 3 A were used.

**Measured time of tested specimens from S25 to S32**

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S25	97-L1	no failure / interruption
	98-L2	no failure / interruption
	99-L3	no failure / interruption
	100-PEN	no failure / interruption
S26	101-L1	no failure / interruption
	102-L2	no failure / interruption
	103-L3	no failure / interruption
	104-PEN	no failure / interruption
S27	105-L1	no failure / interruption
	106-L2	no failure / interruption
	107-L3	no failure / interruption
	108-PEN	no failure / interruption
S28	109-L1	no failure / interruption
	110-L2	no failure / interruption
	111-L3	no failure / interruption
	112-PEN	no failure / interruption
S29	113-L1	no failure / interruption
	114-L2	no failure / interruption
	115-	no failure / interruption
	116-PEN	no failure / interruption
S30	117-L1	no failure / interruption
	118-L2	no failure / interruption
	119-L3	no failure / interruption
	120-PEN	no failure / interruption
S31	121-L1	64:53
	122-L2	x
	123-L3	x
	124-PEN	x
S32	125-L1	x
	126-L2	x
	127-L3	55:21
	128-PEN	x

Specimens 25,26: cables (N)HXH 4x1,5 RE FE180 PH90/E90
Specimens 27,28: cables (N)HXH 4x50 RM FE180 PH30/E30-E60
Specimens 29,30: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90
Specimens 31,32: cables (N)HXCH 4x50/25 RM FE180 PH30/E30-E60

- x** conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W. Circuit breakers with rating 3 A were used.

**Measured time of tested specimens from S33 to S36**

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S33	129-L1	no failure / interruption
	130-L2	no failure / interruption
	131-L3	no failure / interruption
	132-PEN	no failure / interruption
S34	133-L1	no failure / interruption
	134-L2	no failure / interruption
	135-L3	no failure / interruption
	136-PEN	no failure / interruption
S35	137-L1	17:11
	138-L2	x
	139-L3	x
	140-PEN	x
S36	141-L1	x
	142-L2	62:20
	143-L3	x
	144-PEN	x

Specimens 33,34: cables (N)HXH 4x1,5 RE FE180 PH90/E90
--

Specimens 35,36: cables (N)HXH 4x50 RM FE180 PH30/E30-E60
---

- x** conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.  
Circuit breakers with rating 3 A were used.

### Measured time of tested specimens from S53 to S74


Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S53A	213-L	no failure / interruption
	214-PEN	no failure / interruption
S53B	215-L	no failure / interruption
	216-PEN	no failure / interruption
S54A	217-L	no failure / interruption
	218-PEN	no failure / interruption
S54B	219-L	no failure / interruption
	220-PEN	no failure / interruption
S55A	221-L	38:41
	222-PEN	x
S55B	223-L	41:31
	224-PEN	x
S59A	237-L	65:28
	238-PEN	x
S59B	239-L	75:09
	240-PEN	x
S63A	253-L	no failure / interruption
	254-PEN	no failure / interruption
S63B	255-L	48:51
	256-PEN	x
S64B	259-L	no failure / interruption
	260-PEN	no failure / interruption
V70A	281-L	no failure / interruption
	282-PEN	no failure / interruption
V70B	283-L	no failure / interruption
	284-PEN	no failure / interruption
V71A	285-L	81:54
	286-PEN	x
V71B	287-L	no failure / interruption
	288-PEN	no failure / interruption
V74A	297-L	no failure / interruption
	298-PEN	no failure / interruption
V74B	299-L	no failure / interruption
	300-PEN	no failure / interruption

Specimens 53A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90
Specimens 54A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90
Specimens 55A,B: cables HTKSHekw 1x2x0,8 FE180 PH90/E30-E90
Specimens 59A,B: cables HTKSHekw 1x2x0,8 FE180 PH90/E30-E90
Specimens 63A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90
Specimen 64B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90
Specimens 70A,B: cables HTKSHekw 1x2x0,8 FE180 PH90/E30-E90
Specimens 71A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90
Specimens 74A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90

x conductor was turned off manually after permanent interruption / failure of other conductors in the cable

Signal cables were tested by three-phase voltage supply 1 x 110V with LED diodes 3V / 0,03W. Circuit breakers with rating 3 A were used.



## Layout of cables in the test furnace



Specimens 1,2: cables (N)HXCH 4x50/25 RM FE180 PH90/E90	Specimens placed in the basket cable tray (BAKS) Suspension track No.1
Specimens 3,4: cables (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	
Specimens 5,6: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	
Specimen 7: cable (N)HXH 4x1,5 RE FE180 PH90/E90	Specimen with box WKE (Spelsberg)
Specimen 8: cable (N)HXH 4x50 RM FE180 PH30/E30-E60	Specimens placed in the basket cable tray (BAKS) Suspension track No.1
Specimen 9: cable (N)HXH 4x50 RM FE180 PH30/E30-E60	
Specimens 10,11: cables (N)HXH 4x50 RM FE180 PH90/E90	
Specimens 12,13: cables (N)HXH 4x1,5 RE FE180 PH90/E90	Specimens placed in the basket cable tray (BAKS) Suspension track No.2
Specimens 14,15: cables (N)HXCH 4x1,5/1,5 RE FE180 PH30/E30-E60	
Specimen 16: cables (N)HXH 4x1,5 RE FE180 PH30/E30-E60	
Specimen 17: cable (N)HXH 4x1,5 RE FE180 PH30/E30-E60	Specimens placed in the basket cable tray (BAKS) Suspension track No.3
Specimens 18,19: cables (N)HXH 4x1,5 RE FE180 PH90/E90	
Specimen 20: cable (N)HXH 4x1,5 RE FE180 PH90/E90	Specimen placed in ceiling profile ledges with clips UKO (BAKS) in spacing of 600 mm with box WKE (Spelsberg)
Specimens 21,22: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	Specimens placed in the cable tray (BAKS) Suspension track No.4
Specimens 23,24: cables (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	
Specimens 25,26: cables (N)HXH 4x1,5 RE FE180 PH90/E90	
Specimens 27,28: cables (N)HXH 4x50 RM FE180 PH30/E30-E60	Specimens placed in the ladder (BAKS) Suspension track No.4
Specimens 29,30: cables (N)HXCH 4x1,5/1,5 RE FE180 PH90/E90	
Specimens 31,32: cables (N)HXCH 4x50/25 RM FE180 PH30/E30-E60	
Specimens 33,34: cables (N)HXH 4x1,5 RE FE180 PH90/E90	
Specimens 35,36: cables (N)HXH 4x50 RM FE180 PH30/E30-E60	
Specimens 53A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90	Specimens placed in ceiling clips UEF (BAKS) in spacing of 600 mm
Specimens 54A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90	Specimens placed in the basket cable tray (BAKS) Suspension track No.2
Specimens 55A,B: cables HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	
Specimens 59A,B: cables HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	Specimens placed in the basket cable tray (BAKS) Suspension track No.3
Specimens 63A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90	Specimen placed in ceiling profile ledges with clips UKO (BAKS) in spacing of 600 mm
Specimen 64B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90	Specimens placed in ceiling clips UDF (BAKS) in spacing of 600 mm
Specimens 70A,B: cables HTKSHekw 1x2x0,8 FE180 PH90/E30-E90	Specimens placed in the cable tray (BAKS) Suspension track No.4
Specimens 71A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90	
Specimens 74A,B: cables HTKSH 1x2x0,8 FE180 PH90/E30-E90	Specimens placed in the ladder (BAKS) Suspension track No.4




## Photos taken before the test




**Photos taken after the termination of the test**







 <b>FIRES s.r.o.</b> POŽIARNA ODOLNOSŤ FIRE RESISTANCE	Dátum/Date <i>20.11.2008</i>	Podpis/Signature <i>[Signature]</i>
	Dokument č. / Document No. <i>FIRES-FR-235-01-AW5</i>	



Pos.1		Pos.2		Pos.3
A	Typ	A	Typ	Typ
60	K352504H60/3-E			CMOP-40H40-02-E
100	K352100H60/3-E			
150	K352150H60/3-E			CMOP-40H40-03-E
200	K352200H60/3-E			CMOP-40H40-04-E
300	K352300H60/3-E			CMOP-40H40-05-E
400	K352400H60/3-E			

9	8	7	6	5	4	3	2	1
1	2	3	4	5	6	7	8	9
10	11	12	13	14	15	16	17	18
19	20	21	22	23	24	25	26	27
28	29	30	31	32	33	34	35	36
37	38	39	40	41	42	43	44	45
46	47	48	49	50	51	52	53	54
55	56	57	58	59	60	61	62	63
64	65	66	67	68	69	70	71	72
73	74	75	76	77	78	79	80	81
82	83	84	85	86	87	88	89	90
91	92	93	94	95	96	97	98	99
100	101	102	103	104	105	106	107	108
109	110	111	112	113	114	115	116	117
118	119	120	121	122	123	124	125	126
127	128	129	130	131	132	133	134	135
136	137	138	139	140	141	142	143	144
145	146	147	148	149	150	151	152	153
154	155	156	157	158	159	160	161	162
163	164	165	166	167	168	169	170	171
172	173	174	175	176	177	178	179	180
181	182	183	184	185	186	187	188	189
190	191	192	193	194	195	196	197	198
199	200	201	202	203	204	205	206	207
208	209	210	211	212	213	214	215	216
217	218	219	220	221	222	223	224	225
226	227	228	229	230	231	232	233	234
235	236	237	238	239	240	241	242	243
244	245	246	247	248	249	250	251	252
253	254	255	256	257	258	259	260	261
262	263	264	265	266	267	268	269	270
271	272	273	274	275	276	277	278	279
280	281	282	283	284	285	286	287	288
289	290	291	292	293	294	295	296	297
298	299	300	301	302	303	304	305	306
307	308	309	310	311	312	313	314	315
316	317	318	319	320	321	322	323	324
325	326	327	328	329	330	331	332	333
334	335	336	337	338	339	340	341	342
343	344	345	346	347	348	349	350	351
352	353	354	355	356	357	358	359	360
361	362	363	364	365	366	367	368	369
370	371	372	373	374	375	376	377	378
379	380	381	382	383	384	385	386	387
388	389	390	391	392	393	394	395	396
397	398	399	400	401	402	403	404	405
406	407	408	409	410	411	412	413	414
415	416	417	418	419	420	421	42	

This drawing and its contents is the property of the BAK3 company and may not be copied or otherwise disclosed to any third party without our consent. Counterfeits will be prosecuted.

 <b>FIRES</b> S.T.O. POŽIARNÁ OGOLNOST FIRE RESISTANCE	Datum/Date <i>20.12.2002</i>
	Podpis/Signature <i>[Signature]</i>
Dokument č. <i>FIRES-PR-255-04-ANNE</i> Document No.	
Príloha č./Appendix No. <i>13</i>	




**System odporności  
ogniowej E-90**

BAKS  
SOCIAL KINSTRUCKY BY  
1. Jorgine 5 05-480



KDS□400H60/3-E

or




	Datum/Date	20. 12. 2004
	Podpis/Signature	<i>[Signature]</i>
Dokument č. FIRES-FR-235-01-AWE Document No.		
Příloha č. 1 k projektu		



	Název projektu KDS 400H60/3	Systém A4
Název KDS 400H60/3	Systém A4	Systém A4
Název KDS 400H60/3	Systém A4	Systém A4
Název KDS 400H60/3	Systém A4	Systém A4




 <b>FIRES s.r.o.</b> POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 20.12.2008
	Podpis/Signature <i>[Signature]</i>
Dokument & Document No. <i>FIRES-FR-235-OR-ANIE</i>	
Priloha &/Priloha No. <i>15</i>	

B	Typ
215	CWDP40H40/02
315	CWDP40H40/03
415	CWDP40H40/04
515	CWDP40H40/05




	Odchyłka wyników niedługości		Materiał Ciężar Nr normy PN-EN 10327-2005 podfabrykat (nr normy?)	Masa (kg) 1/2	Rozmiar 1/2	Format A4
Projektował	J.GROCHOWSKI	Podpis _____ _____ _____ _____	2010.05	Nazwa rysunku <b>CWDP40H40/...</b>		
Wykonał	J.Grochowski		2010.05			
Sprawił	T.WŁODARCZYK		2010.05			
Zatwierdził	J.KLICZEK		2010.05			
 Profesjonalne Systemy Tras Kablowych			Nr rysunku _____			Nr zmiany _____ _____ _____




 <b>FIRES S.p. o.</b> POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 20.12.2004
	Podpis/Signature 
Dokument o. Document No. <i>FIRES-FR-235-OK.000E</i>	
Priloha o./Appendix No. <i>16</i>	

	Odchyłki wymiarów nietolerowanych		Materiał Gatunek Nr normy półfabrykat (nr normy)		Masa (kg) PN EN 10327/2005	Podziałka 1:1	Format A4
	Projektował T.Grudziński		Data 2004.12.29		Nazwa rysunku <i>USDV</i>		
Rysował J.Jasik		Data 2004.12.29		Nr programu maszynowego ---			Nr zmiany 1
Sprawdzał J.Kliczek		Data 2004.12.29		Nr rysunku ---			1
Zatwierdził J.Kliczek		Data 2004.12.29		Nr rysunku ---			1
 Profesjonalne Systemy Tras Kablowych							



WKSD60



KDS060H60

SPSD60

	Datum/Date 20. 2. 2007	
	Podpis/Signature 	
Dokument No. PIREs - PR-235-04. AWK		
3. Inne uwagi i uwagi		



	Długość wymiarów nie tolerancyjnych	Gatunek Nr. normy podfabrykat (w normy) 1912-2007	Masa (kg)	Podziałka 1:1	Format A4
Nazwa ZAWIESIE DO KDS060H60			Nr. rysunku 1		
Data 19.12.2007			Nr. zmiany 1		



Profesjonalne Systemy  
Iris Kablewych














 FIRES S.T.O. POŻIARNA ODDŁOŚĆ FIRE RESISTANCE	Datum/Date 20.4.2024
	Podpis/Signature 
Dokument 6. Document No. FIRES-FR-255-04-ANNE	
Příloha 6./Appendix No. 19	

	(Balkon) (wykonany) (metalizowany)	Materiał Gatunek Nr normy półfabrykat (nr normy)	Masa (kg) Podziałka 1:1	Format A4 Krawędź Krawędź
Projektował Rysował Sprawdzał Zatwierdził	Nazwa Podpis Data	Nazwa rysunku WKSD60		
Nr programu maszynowego Nr rysunku		Nr zmiany		
 Profesjonalne Systemy Tras Kablowych				




 <b>FIRES S.I.O.</b> POŻIARNA ODPOORNOSĆ FIRE RESISTANCE	Datum/Date 20.12.2007 Podpis/Signature 
	Dokument & Document No. <b>FIRES-FR-235-04 PAGE</b>
Priloga B/Appendix No. <b>20</b>	


	Odchyłka Wykonania nietolerowanych		Materiał Nr normy półfabrykat (nr normy)	Masa (kg) Poziorność 1:1	Format A4 Kształt Kształt
Projektował Rysował Sprawdził Zatwierdził	Nazwisko Podpis	Data 20.12.2007	Nazwa rysunku <b>SKD60</b>		
Nr programu maszynowego			Nr ziany		
Nr rysunku					
 Profesjonalne Systemy Tras Kablowych					




19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71																													




This drawing and its contents is the property of the MDC company and may not be copied or altered disclosed to any third party without our consent. Contraventions will be prosecuted





 <b>FIRES S.J.O.</b> POŻIARNA ODŁYKOWOŚĆ FIRE RESISTANCE	Datum/Date 20.12.2024 Podpis/Signature 
	Dokument 5. Document No. <b>FIRES-FR-235-04. RWG</b>
Załącznik 5./Appendix No. <b>22</b>	


	Długość wymiarów metrowych	Materiał	Grubość Nr normy PN-EN 13501-1	Masa kg/m	Płaskość mm/m	Ciężar N/m
Projektant Pyszał Górecki Zatwierdził	Nazwa Trasy	Data 20.12.2024	Nr projektu 13501-1	Nr zesty 22	Profesjonalne Systemy Tras Kablowych	
Batizowce 51 tydzień						






 <b>FIRES S.r.o.</b> POŻIARNA ODPORNOŚĆ FIRE RESISTANCE	Datum/Date 20.12.2008  Podpis/Signature
	Dokument & Document No. <i>FIRES-FD-235-OK AWG</i>
Załącznik &/Appendix No. <i>23</i>	


 	Długość wymiarów netto/Net dimensions	Materiał for name polski/English (for name)	Grubość for name mm/mm	Rodzaj for name mm/mm	Format A4	
Projektant rysownik sprawdzający zatwierdzający	Nazwa _____ _____ _____ _____	Rodzaj _____ _____ _____ _____	Rodzaj _____ _____ _____ _____	Rodzaj _____ _____ _____ _____	Rodzaj _____ _____ _____ _____	
Profesjonalne Systemy Tras Kablowych					Batizowce 51 tydzień	







 <b>FIRES s.r.o.</b> POŻARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 20.12.2008
	Podpis/Signature 
Dokument č. Document No. <i>FIRES-PA-235-01.1NGE</i>	
Příloha č./Appendix No. <i>24</i>	


 	Długość wykładziny m	Szerokość m	Materiał polifabrykat (nie normy)	Data 05-Maj-06	Nazwa Półfabrykatu	Masa kg	Płaskość mm	Grubość mm	Format A4
Projektant Pyskowski Sprawdził Zastępcą	Nazwa J. Brachowski	Podpis 	Data 05-Maj-06	Nr programu maszynowego Nr rysunku	Nr zleceń				
Profesjonalne Systemy Tras Kablowych						Batizowce 51 tydzień			



 FIRES S.T.O. POZIARNA OPORNOST FIRE RESISTANCE	Datum/Date 20.12.2008
	Podpis/Signature 
Dokument & Document No. FIRES-PR-235-OK-PWS	
Polichia & Kopero's No. 35	

	Dłuchyłka wymiarów niestandardowych		Materiał Galunek Nr normy PN-EN 10327:2005 półfabrykat (nr normy)		Masa (kg)	Podziałka 1:1	Format A4
	Projektował Rysował Sprawdził Zatwierdził		Nazwa rysunku 28-Jun-08	Nr programu maszynowego Nr rysunku		Nr zmiany	
 Profesjonalne Systemy Tras Kablowych							








	A	B	C	E	F	G
UEFS	38	14	12	5	R25	R24
UEF6	40	14	12	6	R3	R24
UEF7	42	14	12	7	R35	R24
UEF8	44	14	12	8	R4	R24
UEF9	46	14	12	9	R45	R24
UEF10	48	14	12	10	R5	R24
UEF12	52	14	12	12	R6	R24
UEF14	58	20	2	15	R7	R4
UEF15	60	20	2	16	R75	R4
UEF16	62	20	2	17	R8	R4
UEF18	66	20	2	19	R9	R4
UEF20	70	20	2	21	R10	R4
UEF22	74	20	2	23	R11	R4
UEF25	80	20	2	26	R125	R4

 <b>FIRES s.r.o.</b> POŻIARNA ODŁOŚĆ FIRE RESISTANCE	Datum/Date 20.12.2008 Podpis/Signature 
	Dokument č. Document No. <b>FIRES-FR-235-04-AUG</b>
Příloha č. 1/Appendix No. <b>26</b>	

	Odkrytý odkryty odkryty	Nizozem Nizozem Nizozem	Počet Počet Počet	Materiál Materiál Materiál	Odstup Odstup Odstup	Rozměr Rozměr Rozměr	Počet Počet Počet	Materiál Materiál Materiál
					Pro normy Pro normy Pro normy	PN-EN 1242 + A1:1997	11	A4
Projektant Projektant Projektant	JORDHOVIXI JORDHOVIXI JORDHOVIXI	Počet Počet Počet	201004 201004 201004	Materiál Materiál Materiál	UEF UEF UEF	Pro normy Pro normy Pro normy	11	A4
Systém Systém Systém	JORDHOVIXI JORDHOVIXI JORDHOVIXI	Počet Počet Počet	201004 201004 201004	Materiál Materiál Materiál	UEF UEF UEF	Pro normy Pro normy Pro normy	11	A4
Správní Správní Správní	JORDHOVIXI JORDHOVIXI JORDHOVIXI	Počet Počet Počet	201004 201004 201004	Materiál Materiál Materiál	UEF UEF UEF	Pro normy Pro normy Pro normy	11	A4
Závěr Závěr Závěr	JORDHOVIXI JORDHOVIXI JORDHOVIXI	Počet Počet Počet	201004 201004 201004	Materiál Materiál Materiál	UEF UEF UEF	Pro normy Pro normy Pro normy	11	A4
Profesionální Systémy Trasy Kabelových								



	A	B	C	E	F	G
UDF5	23	14	12	5	R25	R24
UDF6	24	14	12	6	R3	R24
UDF7	25	14	12	7	R35	R24
UDF8	26	14	12	8	R4	R24
UDF9	27	14	12	9	R45	R24
UDF10	28	14	12	10	R5	R24
UDF12	30	14	12	12	R6	R24
UDF14	33	20	2	15	R7	R4
UDF15	34	20	2	16	R75	R4
UDF16	35	20	2	17	R8	R4
UDF18	37	20	2	19	R9	R4
UDF20	39	20	2	21	R10	R4
UDF22	41	20	2	23	R11	R4
UDF25	44	20	2	26	R125	R4

 <b>FIRES s.r.o.</b> POŻIARNA ODOLNOŚĆ FIRE RESISTANCE	Datum/Date 10.12.2004
	Podpis/Signature 
Dokument & Document No. <b>FIRES-FR-255-04-1AWE</b>	
Priloha &/Appendix No. <b>28</b>	

 	Dohybný symetrický nekolezaných	Materiál GRC-0VSK1	Datum 20.10.04	GRC-0VSK1	PN-EN 10442 + A1:1997	1/1	A4
Projektant J.GROD-0VSK1	Názov J.GROD-0VSK1 T. WLODARCZYK	Podpis 	20.10.04	1/1			
Projektant J.GROD-0VSK1			20.10.04	1/1			
Správca T. WLODARCZYK			20.10.04	1/1			
Zastupiteľ J.GROD-0VSK1			20.10.04	1/1			
Profesionálne Systémy Trasy Káblových			UDF				